



STATE LOAD DESPATCH CENTER

OFFICE OF THE CHIEF LOAD DESPATCHER

ODISHA POWER TRANSMISSION CORPORATION LIMITED

GRIDCO Colony, P.O: Mancheswar Rly. Colony, Bhubaneswar-17, FAX:0674-2748509

CIN - U40102OR2004SGC007553

REACTIVE ENERGY (VARh) EXCHANGE OF THE UTILITIES WITH THE POOL For the Month of JUL - 2021 (MOCK EXERCISE)

Sl. No.	BENEFICIARY	Net Reactive Energy High (Voltage > 103%) in MVARh	Reactive Charge_MVARH(Rs.)	Net Reactive Energy Low (Voltage < 97%) in MVARh	Reactive Charge_MVARL(Rs.)	Net Reactive Charges(Rs.)
			@3Paisa/KvArH		@3Paisa/KvArH	
1	CESU	-14968.910576	-449067.32	19270.513936	578115.42	-1027182.74
2	IMFA	5142.300000	154269	0.000000	0	154269
3	NALCO	0.000000	0	0.000000	0	0
4	NESCO	-7357.949392	-220738.48	21475.050000	644251.5	-864989.98
5	SOUTHCO	-8935.530000	-268065.9	7891.090096	236732.7	-504798.6
6	WESCO	-26223.550552	-786706.52	21511.818032	645354.54	-1432061.06
	Total	-52343.64052	-1570309.22	70148.472064	2104454.16	-3674763.38

Note:

- 1) For Net reactive energy, (+) means drawl by the beneficiary and (-) means injection by the beneficiary
- 2) For Net reactive Charges, (+) means receivable by the beneficiary and (-) means payable by the beneficiary