

REVISED EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH JULY -2017

EXPORT TTC/ATC

SL. No.	Month	Export TTC	Reliability Margin	Counterflow on account of Surrender of LTA(ISGS)	Export ATC	Contingency	Assumptions
2	JULY-2017	13	60 MW (2% of load assumed)	300 MW	253 MW	Outage of one 220kV Jayanagar-Jeypore(PG) Ckt.	Generation: 3086 MW Load: 3000 MW

IMPORT TTC/ATC

SL. No.	Month	Import TTC	Reliability Margin	Import LTA(ISGS)	Import ATC	Contingency	Assumptions
2	JULY-2017	2188 MW	78 MW (2% of load assumed)	1200 MW	910 MW	Outage of one 220kV Meramundali-Bhanjanagar Ckt.	Generation: 1811 MW Load: 3898 MW