

EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTHS JUNE-17 & JULY -17

EXPORT TTC/ATC

SL. No.	Month	Export TTC	Reliability Margin	Counterflow on account of Surrender of LTA(ISGS)	Export ATC	Contingency	Assumptions
1	JUNE-2017	493 MW	62 MW (2% of load assumed)	300 MW	731 MW	Outage of one 220kV Jayanagar-Jeypore(PG) Ckt.	Generation: 3676 MW Load: 3102 MW
2	JULY-2017	596 MW	60 MW (2% of load assumed)	300 MW	836 MW	Outage of one 220kV Jayanagar-Jeypore(PG) Ckt.	Generation: 3676 MW Load: 3001 MW

IMPORT TTC/ATC

SL. No.	Month	Import TTC	Reliability Margin	Import LTA(ISGS)	Import ATC	Contingency	Assumptions
1	JUNE-2017	1110 MW	74 MW (2% of load assumed)	1100 MW	NIL	Outage of one 220kV Meramundali-Bhanjanagar Ckt.	Generation: 2690 MW Load: 3708 MW
2	JULY-2017	1000 MW	72 MW (2% of load assumed)	1100 MW	NIL	Outage of one 220kV Meramundali-Bhanjanagar Ckt.	Generation: 2690 MW Load: 3602 MW