

EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH AUGUST -2018

EXPORT TTC/ATC

SL. No.	Month	Export TTC	Reliability Margin	Counterflow on account of Surrender of LTA(ISGS)	Export ATC	Contingency	Assumptions
1	AUGUST-2018	39 MW	62 MW (2% of load assumed)	0 MW	NIL	Outage of one 220kV Jayanagar-Jeypore(PG) Ckt.	Generation: 3152 MW Load: 3100 MW

IMPORT TTC/ATC

SL. No.	Month	Import TTC	Reliability Margin	Import LTA(ISGS)	Import ATC	Contingency	Assumptions
1	AUGUST-2018	1771 MW	85 MW (2% of load assumed)	1150 MW	536 MW	Outage of one 220kV Meramundali-Bhanjanagar Ckt.	Generation: 2636 MW Load: 4252 MW