

## EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH DECEMBER -2017

### EXPORT TTC/ATC

SL. No.	Month	Export TTC	Reliability Margin	Counterflow on account of Surrender of LTA(ISGS)	Export ATC	Contingency	Assumptions
1	DECEMBER-2017	107 MW	74 MW (2% of load assumed)	0 MW	33 MW	Outage of one 220kV Jayanagar-Jeypore(PG) Ckt.	Generation: 3895 MW Load: 3718 MW

### IMPORT TTC/ATC

SL. No.	Month	Import TTC	Reliability Margin	Import LTA(ISGS)	Import ATC	Contingency	Assumptions
1	DECEMBER-2017	1936 MW	102 MW (2% of load assumed)	1150 MW	684 MW	Outage of one 220kV Meramundali-Bhanjanagar Ckt.	Generation: 3295 MW Load: 5101 MW