

## EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH FEBRUARY -2018

### EXPORT TTC/ATC

SL. No.	Month	Export TTC	Reliability Margin	Counterflow on account of Surrender of LTA(ISGS)	Export ATC	Contingency	Assumptions
1	FEBRUARY-2018	273 MW	46 MW (2% of load assumed)	0 MW	227 MW	Outage of one 220kV Jayanagar-Jeypore(PG) Ckt.	Generation: 2645 MW Load: 2303 MW

### IMPORT TTC/ATC

SL. No.	Month	Import TTC	Reliability Margin	Import LTA(ISGS)	Import ATC	Contingency	Assumptions
1	FEBRUARY-2018	1832 MW	78 MW (2% of load assumed)	1150 MW	604 MW	Outage of one 220kV Meramundali-Bhanjanagar Ckt.	Generation: 2247 MW Load: 3906 MW