

EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH JULY -2018

EXPORT TTC/ATC

| SL. No. | Month | Export TTC | Reliability Margin | Counterflow on account of Surrender of LTA(ISGS) | Export ATC | Contingency | Assumptions |
|---------|-----------|------------|-------------------------------|--|------------|---|--------------------------------------|
| 1 | JULY-2018 | NIL | 62 MW (2% of load assumed) | 0 MW | NIL | Outage of one 220kV Jayanagar-Jeypore(PG) Ckt. | Generation: 3087 MW Load: 3121 MW |

IMPORT TTC/ATC

| SL. No. | Month | Import TTC | Reliability Margin | Import LTA(ISGS) | Import ATC | Contingency | Assumptions |
|---------|-----------|------------|-------------------------------|------------------|------------|---|--------------------------------------|
| 1 | JULY-2018 | 1804 MW | 86 MW (2% of load assumed) | 1150 MW | 568 MW | Outage of one 220kV Meramundali-Bhanjanagar Ckt. | Generation: 2636 MW Load: 4282 MW |