

Odisha Power Transmission Corporation Ltd.
Bhubaneswar.



Agenda
for
143rd Power System Operational Co-ordination Meeting

Date: 07.10.2020
Through Video Conferencing

Agenda for 143rd PSOC Meeting to be held on 07.10.2020 through Video Conferencing

PART A

A. Confirmation of the minutes of the 142nd PSOC Meeting held on 29.02.2020

The minutes of meeting was circulated vide letter No. SGM (PS)-PI-15/2019/798⁽⁴⁸⁾ dated 03.03.2020 to all the members and also uploaded in the SLDC website. Members may offer their comments. If there are no comments, the minutes of the meeting may please be confirmed.

PART B: GRID PERFORMANCE

Review of Grid Performance for the month of August'20.

A. Frequency:

Hourly frequency variation for the month of August '20.

| Month | % of time frequency remained | | | | | Average |
|---------------|------------------------------|-------------|-------------|--------------------|--------|---------|
| | <49.00 | 49.00-49.70 | 49.70-49.90 | 49.90-50.05 | >50.05 | |
| Jun'20 | 0.00 | 0.02 | 4.12 | 75.22 | 20.64 | 50.01 |
| Jul'20 | 0.00 | 0.02 | 6.18 | 77.02 | 16.78 | 50.00 |
| Aug'20 | 0.00 | 0.03 | 5.96 | 78.93 | 15.08 | 50.00 |

Maximum & Minimum frequency during the month of Jul'20 & Aug'20.

| Month | Freq (Hz) | Date | Time |
|---------------|-----------------|----------|-----------|
| Jul'20 | Maximum – 50.39 | 05.07.20 | 03:46 Hrs |
| | Minimum – 49.64 | 14.07.20 | 22:08 Hrs |
| Aug'20 | Maximum – 50.24 | 21.08.20 | 13:33 Hrs |
| | Minimum – 49.60 | 31.08.20 | 19:11 Hrs |

B. Grid Demand up to the month of August'20

| Month | Max. Consumption | | Demand | | Maximum Demand | | | Minimum Demand | | |
|----------------|------------------|-----------------|-------------|-------------|----------------|-----------------|--------------|----------------|-----------------|--------------|
| | MU | Date | MU | Avg. (MW) | MW | Date | Time | MW | Date | Time |
| Apr'20 | 78.62 | 14.04.20 | 2072 | 2878 | 3623 | 14.04.20 | 20:00 | 1755 | 24.04.20 | 19:00 |
| May'20 | 88.30 | 27.05.20 | 2407 | 3236 | 4082 | 26.05.20 | 20:00 | 1995 | 20.05.20 | 13:00 |
| June'20 | 93.97 | 06.06.20 | 2513 | 3490 | 4360 | 06.06.20 | 23:00 | 2163 | 24.06.20 | 24:00 |
| July'20 | 96.86 | 20.07.20 | 2728 | 3667 | 4538 | 18.07.20 | 21:00 | 3027 | 14.07.20 | 06:00 |
| Aug'20 | 94.29 | 28.08.20 | 2626 | 3530 | 4488 | 28.08.20 | 20:00 | 2594 | 26.08.20 | 05:00 |

C. Voltage Profile of 220 kV Buses in OPTCL system for the month of: August'20

| 220 KV | MAXIMUM | | | MINIMUM | | |
|-------------|---------|-----|-------|---------|-----|-------|
| | MAX | DAY | HOUR | MIN | DAY | HOUR |
| Atri | 232.61 | 15 | 5:30 | 219.28 | 1 | 22:45 |
| Balasore | 233.65 | 26 | 6:00 | 213.74 | 1 | 22:30 |
| Barkote | 231.81 | 15 | 16:45 | 224.53 | 4 | 12:00 |
| Bargarh | 229.96 | 27 | 5:45 | 208.77 | 24 | 9:15 |
| Bhadrak | 233.77 | 26 | 6:00 | 197.28 | 9 | 21:15 |
| Bhanjanagar | 236.94 | 26 | 16:00 | 224.70 | 2 | 22:45 |
| Bidanasi | 232.73 | 26 | 6:00 | 217.83 | 1 | 22:45 |
| BolangirN | 232.15 | 27 | 5:45 | 212.93 | 24 | 9:15 |
| Budhipadar | 231.86 | 28 | 6:00 | 226.38 | 12 | 10:45 |
| Chandaka | 231.58 | 26 | 5:45 | 216.85 | 1 | 22:30 |
| Cuttack | 231.58 | 26 | 6:00 | 216.33 | 2 | 23:00 |
| Duburi Old | 233.65 | 26 | 6:00 | 219.16 | 2 | 22:45 |
| Duburi New | 233.02 | 26 | 6:00 | 218.64 | 2 | 22:45 |
| Jayanagar | 241.10 | 15 | 11:30 | 234.52 | 1 | 0:00 |
| Joda | 228.75 | 27 | 5:45 | 219.05 | 31 | 19:15 |
| Katapalli | 228.63 | 27 | 5:45 | 218.99 | 31 | 19:15 |
| Lapanga | 231.00 | 27 | 5:45 | 225.63 | 12 | 16:15 |
| Laxmipur | 241.27 | 20 | 6:45 | 233.08 | 31 | 19:45 |
| Mendhasal | 233.54 | 15 | 5:30 | 219.68 | 1 | 22:30 |
| Meramundali | 232.38 | 15 | 14:00 | 225.28 | 2 | 22:45 |
| Narendrapur | 235.33 | 16 | 17:00 | 218.76 | 1 | 14:45 |
| Nayagarh | 236.54 | 26 | 16:15 | 220.66 | 12 | 12:30 |
| Paradeep | 234.52 | 26 | 6:00 | 207.50 | 1 | 20:45 |
| Tarkera | 236.42 | 27 | 6:00 | 228.57 | 31 | 19:00 |
| Theruvalli | 238.62 | 5 | 6:45 | 226.90 | 1 | 14:45 |
| Rengali | 229.90 | 15 | 16:45 | 223.78 | 23 | 20:30 |

The maximum Voltage of **241.27 kV** occurred at **Laxmipur 220 kV Bus.**, while **Bhadrak 220 kV bus** has experienced the minimum Voltage of **197.28 kV**. The 220 kV Voltage profile of all the major 220kV & 132kV Bus during the month of **Aug'2020** are indicated in System performance presentation. **Members may discuss.**

D. Loading of 220/ 132 kV Auto at 220 kV S/Ss in OPTCL system for the month of Aug– 2020.

| AUTO TRANSFORMER LOADING FOR THE MONTH OF AUGUST 2020 | | | | | | | | |
|--|----------|----------------|---------------|-------|---------|---------------|-------|---------|
| Name of the 220 kV Sub-Station (Feeding Sub-stations/Feeders) | Capacity | Drawal details | | | | | | REMARKS |
| | | Maximum | | | Minimum | | | |
| | | MVA | MW | Day | Time | MW | Day | |
| ATRI {Banki, Khurda, Chandpur & Argul} | 2x160 | 76.04 | 29th Aug 2020 | 12:30 | 26.36 | 23rd Aug 2020 | 17:30 | |
| | | 76.00 | 29th Aug 2020 | 12:30 | 17.88 | 21st Aug 2020 | 9:45 | |
| ASKA NEW | 2x160 | 68.44 | 3rd Aug 2020 | 6:15 | 12.12 | 23rd Aug 2020 | 15:00 | |
| | | 67.92 | 3rd Aug 2020 | 6:15 | 12.04 | 23rd Aug 2020 | 15:00 | |
| BALASORE 220/132 KV { Balasore, Birla Tyre(I), Ispat Alloy(I), Jaleswar, Jaleswar(T)} | 3x160 | 72.96 | 31st Aug 2020 | 0:00 | 19.28 | 3rd Aug 2020 | 17:15 | |
| | | 73.12 | 31st Aug 2020 | 0:00 | 19.12 | 3rd Aug 2020 | 17:15 | |
| | | 72.04 | 31st Aug 2020 | 0:00 | 19.24 | 3rd Aug 2020 | 16:15 | |
| BARGARH 220/132 kV | 1x100 | 27.28 | 13th Aug 2020 | 16:30 | 0.40 | 5th Aug 2020 | 11:15 | |
| | 1x160 | 15.72 | 13th Aug 2020 | 16:30 | 0.04 | 27th Aug 2020 | 13:15 | |
| BHADRAK 220/132 KV {Bargarh, Ghensh} | 1x100 | 45.00 | 6th Aug 2020 | 19:15 | 4.88 | 27th Aug 2020 | 17:45 | |
| | 1x160 | 85.08 | 13th Aug 2020 | 14:30 | 6.16 | 7th Aug 2020 | 17:45 | |
| | 1x160 | 84.88 | 13th Aug 2020 | 14:30 | 11.56 | 24th Aug 2020 | 22:30 | |
| BHANJANAGAR 220/132 KV { Bhanjanagar, Aska, Phulbani, Ganjam, Chatrapur} | 1x160 | 36.96 | 1st Aug 2020 | 14:45 | 6.36 | 16th Aug 2020 | 22:45 | |
| | 1x160 | 50.60 | 27th Aug 2020 | 19:00 | 5.24 | 16th Aug 2020 | 22:45 | |
| BIDANASI 220/132 KV {Bidanasi, Khurda } | 1x100 | 25.68 | 17th Aug 2020 | 10:00 | 0.04 | 7th Aug 2020 | 4:30 | |
| | 1x100 | 17.60 | 17th Aug 2020 | 10:00 | 0.04 | 19th Aug 2020 | 16:45 | |
| | 1x160 | 29.56 | 3rd Aug 2020 | 15:15 | 0.04 | 4th Aug 2020 | 16:45 | |
| BOLANGIR (SADAIPALLI) 220/132 KV { Bolangir, Patnagarh, Sonapur, Saintala, Khariar, Barpalli } | 2x160 | 99.08 | 2nd Aug 2020 | 19:15 | 7.24 | 30th Aug 2020 | 13:00 | |
| | | 99.08 | 2nd Aug 2020 | 19:15 | 7.24 | 30th Aug 2020 | 13:00 | |
| | | 104.60 | 2nd Aug 2020 | 19:15 | 7.68 | 30th Aug 2020 | 13:00 | |
| BUDHIPADAR 220/132 KV { Jharsuguda, Jharsuguda Tr, Cemco(I), MCL, Sundergarh, Brajarajnaragar, Rajgangpur} | 2x160 | 87.32 | 12th Aug 2020 | 11:30 | 14.72 | 2nd Aug 2020 | 2:15 | |
| | | 86.84 | 12th Aug 2020 | 11:30 | 0.04 | 28th Aug 2020 | 5:15 | |
| CHANDAKA 220/132 KV { Chandaka, Bhubaneswar, Nimapada, Ransinghpur, Puri, Kesura, Kaipadar Tr. } | 1x100 | 63.12 | 1st Aug 2020 | 22:45 | 17.40 | 23rd Aug 2020 | 17:15 | |
| | 1x160 | 109.56 | 1st Aug 2020 | 22:45 | 30.60 | 23rd Aug 2020 | 17:15 | |
| | 1x100 | 68.52 | 1st Aug 2020 | 22:45 | 18.88 | 23rd Aug 2020 | 17:15 | |
| | 1x160 | 105.84 | 1st Aug 2020 | 22:45 | 17.48 | 10th Aug 2020 | 13:30 | |
| CUTTACK | 1x160 | 65.68 | 22nd Aug 2020 | 10:45 | 13.04 | 23rd Aug 2020 | 18:00 | |
| | 1x100 | 58.56 | 26th Aug 2020 | 11:45 | 7.92 | 23rd Aug 2020 | 17:45 | |
| DUBURI 220/132 KV {Duburi, Bamnipal(I), BRPL, MESCO, Jajpur Road, Kalarangi, Jajpur Town} | 1x160 | 59.48 | 2nd Aug 2020 | 20:00 | 0.08 | 18th Aug 2020 | 15:15 | |
| | 1x100 | | | | | | | |
| | 1x100 | 35.88 | 2nd Aug 2020 | 20:00 | 0.04 | 4th Aug 2020 | 15:00 | |
| GODA | 1x160 | | | | | | | |
| 1x100 | | | | | | | | |
| JAYAPATNA 220/132 KV. | | | | | | | | |
| JAYANAGAR 220/132 KV. {Damanjodi(NALCO), Traction S/S, Tentulikhunti, Sunabeda, Jayanagar} | 1x160 | 43.92 | 8th Aug 2020 | 19:30 | 0.04 | 26th Aug 2020 | 4:15 | |
| | 1x160 | 43.88 | 8th Aug 2020 | 19:30 | 0.04 | 26th Aug 2020 | 5:30 | |
| JODA 220/132 KV { Joda, Tensa, FAP(I), Bolani(I), Nalda Tr., Polasponga, *Rairangpur, Bhalulata traction} | 3x100 | 66.16 | 1st Aug 2020 | 22:30 | 20.60 | 20th Aug 2020 | 15:00 | |
| | 3x160 | 74.36 | 13th Aug 2020 | 19:45 | 24.60 | 20th Aug 2020 | 15:00 | |
| | 3x100 | 66.04 | 1st Aug 2020 | 22:30 | 15.52 | 2nd Aug 2020 | 15:45 | |
| KATAPALI 220/132 KV {Chipilima, Bargarh, ACC, Sonapur & Katapali area load.} | 1x100 | 27.68 | 19th Aug 2020 | 15:15 | 0.04 | 3rd Aug 2020 | 18:00 | |
| | 1x100 | 27.80 | 19th Aug 2020 | 15:15 | 0.04 | 3rd Aug 2020 | 21:30 | |
| | 1x160 | 47.28 | 10th Aug 2020 | 19:15 | 0.04 | 5th Aug 2020 | 13:15 | |
| LAPANGA {Kuchinda, Aryan Viraj, Shyam Metallics} | 2x160 | 72.32 | 10th Aug 2020 | 19:30 | 17.44 | 28th Aug 2020 | 2:15 | |
| | | 72.12 | 10th Aug 2020 | 19:30 | 17.32 | 28th Aug 2020 | 2:15 | |
| MERAMUNDALI 220/132 kV {Meramundali Traction, Dhenkanal, Navchrome(I), Hind Metal, Aarti, BRG} | 3x100 | 43.76 | 31st Aug 2020 | 0:00 | 0.68 | 8th Aug 2020 | 12:45 | |
| | | 43.00 | 31st Aug 2020 | 0:00 | 1.04 | 8th Aug 2020 | 12:45 | |
| | | 70.44 | 21st Aug 2020 | 15:30 | 0.60 | 19th Aug 2020 | 19:00 | |
| Mendhasal { Part area load of Khurda S/S} | 2x100 | 40.12 | 10th Aug 2020 | 13:30 | 7.99 | 23rd Aug 2020 | 17:15 | |
| | | 37.82 | 10th Aug 2020 | 13:30 | 7.64 | 23rd Aug 2020 | 17:15 | |
| NARENDRAPUR 220/132KV { Narendrapur, NarendrapurTr, Berhampur, Chhatrapur, Ganjam, Balugaon, Digapahandi, Mohana.} | 2x160 | 97.00 | 30th Aug 2020 | 18:45 | 36.60 | 8th Aug 2020 | 16:00 | |
| | | 93.40 | 30th Aug 2020 | 18:45 | 35.44 | 8th Aug 2020 | 16:00 | |
| | 1x100 | 53.96 | 30th Aug 2020 | 18:45 | 19.64 | 20th Aug 2020 | 12:00 | |
| PARDEEP 220/132 KV { Paradeep, Kendrapada, Pattamundai, Chandikhol, Cuttack, Jagatsinghpur, Phulnakhara} | 1x100 | 61.84 | 1st Aug 2020 | 21:00 | 12.48 | 4th Aug 2020 | 16:45 | |
| | 1x160 | 107.28 | 3rd Aug 2020 | 4:30 | 24.88 | 26th Aug 2020 | 15:45 | |
| | 1x160 | 99.88 | 3rd Aug 2020 | 4:30 | 19.28 | 4th Aug 2020 | 16:45 | |
| TARKERA 220/132 KV { Rourkela, Rourkela Tr., RSP(I), Chhend , Adhunik Metal, Rajgangpur, OCL(I), Rajgangpur Tr.} | 4x100 | 60.36 | 25th Aug 2020 | 11:00 | 6.08 | 4th Aug 2020 | 21:00 | |
| | | 64.16 | 25th Aug 2020 | 11:00 | 7.92 | 4th Aug 2020 | 21:00 | |
| | | 53.96 | 2nd Aug 2020 | 2:45 | 6.16 | 4th Aug 2020 | 21:00 | |
| THERUVALLI 220/132 KV. {Theruvalli, IMFAL(I), JK(I), Junagarh, Kesinga, Powmex(I), Rayagada, } | 2x100 | 60.56 | 20th Aug 2020 | 10:30 | 13.20 | 6th Aug 2020 | 11:45 | |
| | | 64.08 | 20th Aug 2020 | 10:30 | 13.36 | 6th Aug 2020 | 11:45 | |
| | 1x160 | 78.12 | 30th Aug 2020 | 19:30 | 21.04 | 6th Aug 2020 | 11:45 | |
| TTPS 220/132 KV {Chainpal, FCI (I), Angul, MCL Nandira(I), Rairakhole, Boinda, Kamakhyannagar, Kalarangi, Nuapatna, | 1x160 | 55.67 | 30th Aug 2020 | 23:30 | 0.00 | 19th Aug 2020 | 19:00 | |
| | 1x160 | 55.67 | 30th Aug 2020 | 23:30 | 0.00 | 19th Aug 2020 | 19:00 | |
| SAMANGARA {Puri, Nimapara & Konark} | 2x160 | | | | | | | |

*** - Alternate P/S from Kucheil.

Supported by Burla & Chipilima power.

Rayagada & Paralakhemundi can be fed from Mchhkkund system.

| ICT LOADING FOR THE MONTH OF AUGUST 2020 | | | | | | | | |
|--|----------|----------------|--------------|-------|---------|---------------|-------|---------|
| Name of the 400 kV Sub-Station | Capacity | Drawal details | | | | | | REMARKS |
| | | Maximum | | | Minimum | | | |
| | MVA | MW | Day | Time | MW | Day | Time | |
| MERAMUNDALI | 2x315 | 172.00 | 6th Aug 2020 | 19:45 | 14.40 | 21st Aug 2020 | 9:15 | |
| | | 174.00 | 6th Aug 2020 | 19:45 | 14.40 | 21st Aug 2020 | 9:15 | |
| MENDHASAL | 2x315 | 180.00 | 3rd Aug 2020 | 15:15 | 63.60 | 16th Aug 2020 | 0:15 | |
| | | 180.40 | 3rd Aug 2020 | 15:00 | 63.60 | 16th Aug 2020 | 0:15 | |
| | | 179.20 | 3rd Aug 2020 | 15:15 | 63.20 | 16th Aug 2020 | 0:15 | |
| DUBURI(N) | 2x315 | 147.20 | 7th Aug 2020 | 14:00 | 1.60 | 26th Aug 2020 | 3:00 | |
| | | 147.60 | 7th Aug 2020 | 14:00 | 2.00 | 26th Aug 2020 | 3:00 | |
| LAPANGA | 2x315 | 195.60 | 1st Aug 2020 | 16:15 | 0.40 | 18th Aug 2020 | 16:30 | |
| | | 194.40 | 1st Aug 2020 | 16:15 | 0.40 | 24th Aug 2020 | 9:15 | |

E. DISCOM Drawal up to the month of August'20

| Name of DISCOM | Month | Approved Energy Drawal Prorated for the month (MU) | Schedule Energy (MU) | Actual Energy Drawal (MU) | Open Access Import Schedule (MU) | Net Energy Drawal (MU) | Overdra w (MU) |
|----------------|---------|--|----------------------|---------------------------|----------------------------------|------------------------|----------------|
| | | 1 | 2 | 3 | 4 | 5=(3-4) | 6=(5-2) |
| CESU | Apr'20 | 634.710 | 800.548 | 674.119 | 6.251 | 667.868 | -132.68 |
| | May'20 | 727.216 | 804.301 | 768.907 | 20.500 | 748.407 | -55.894 |
| | June'20 | 775.777 | 778.356 | 798.750 | 23.199 | 775.551 | -2.805 |
| | July'20 | 799.093 | 804.301 | 850.070 | 21.005 | 829.065 | 24.764 |
| | Aug'20 | 775.480 | 775.480 | 860.439 | 75.109 | 785.330 | 9.850 |
| WESCO | Apr'20 | 560.137 | 636.986 | 526.273 | 0.854 | 525.419 | -111.567 |
| | May'20 | 607.764 | 679.452 | 654.793 | 47.142 | 607.651 | -71.801 |
| | June'20 | 586.827 | 657.534 | 664.137 | 73.051 | 591.086 | -66.448 |
| | July'20 | 664.178 | 679.452 | 789.847 | 118.134 | 671.713 | -7.739 |
| | Aug'20 | 640.848 | 640.848 | 720.326 | 85.016 | 635.31 | -5.538 |
| NESCO | Apr'20 | 357.804 | 518.630 | 446.171 | 85.613 | 360.558 | -158.072 |
| | May'20 | 397.609 | 558.000 | 517.004 | 120.062 | 396.942 | -161.058 |
| | June'20 | 428.017 | 540.000 | 581.647 | 153.240 | 428.407 | -111.593 |
| | July'20 | 463.731 | 558.000 | 602.024 | 130.653 | 471.371 | -86.629 |
| | Aug'20 | 435.361 | 435.361 | 577.306 | 135.822 | 441.484 | 6.123 |
| SOUTHCO | Apr'20 | 278.425 | 332.055 | 280.019 | 0.000 | 280.019 | -52.036 |
| | May'20 | 318.751 | 343.973 | 319.052 | 0.588 | 318.464 | -25.509 |
| | June'20 | 306.340 | 332.877 | 297.700 | 2.069 | 295.631 | -37.246 |
| | July'20 | 315.565 | 343.973 | 318.889 | 0.656 | 318.233 | -25.74 |
| | Aug'20 | 319.800 | 319.800 | 319.423 | 1.304 | 318.119 | -1.681 |

The figures are as per EBC data. Energy drawal by SOUTHCO are excluding of energy consumed by NALCO at Damanjodi and IMFA at Theruvali.

Members may please discuss.

F. Energy Generation / Import up to the month of August'20

Figures in MU

| Month | Thermal (TTPS+IbTTPS) | OHPC & MKD | CGP Support | IPP Inj. | RE | ISGS | Total |
|----------|-----------------------|------------|-------------|----------|-------|--------|---------|
| April'20 | 919.10 | 591.31 | 154.39 | 337.05 | 55.73 | 14.40 | 2071.97 |
| May'20 | 1022.44 | 609.54 | 225.72 | 444.16 | 64.24 | 41.36 | 2407.45 |
| June'20 | 1028.62 | 550.29 | 232.58 | 403.95 | 66.64 | 230.98 | 2513.06 |

| | | | | | | | |
|--------------|----------------|----------------|----------------|----------------|---------------|---------------|-----------------|
| July'20 | 1058.39 | 707.17 | 303.57 | 403.90 | 69.48 | 186.06 | 2728.56 |
| Aug'20 | 875.48 | 696.47 | 236.07 | 437.95 | 67.69 | 312.54 | 2626.20 |
| Total | 4904.03 | 3154.78 | 1152.33 | 2027.01 | 323.78 | 785.34 | 12347.24 |

G. Drawal of Machhakund Power

The drawal of Machhakund power up to the month of **August'20** are as detailed:

| Month | Total Generation | | Odisha Drawl | | AP Drawl | |
|--------------|------------------|---------------|----------------|---------------|----------------|--------------|
| | MU | Avg (MW) | MU | Avg (MW) | MU | Avg (MW) |
| Apr'20 | 57.086 | 79.29 | 25.622 | 35.59 | 29.349 | 40.76 |
| May'20 | 55.641 | 77.28 | 24.205 | 33.62 | 29.303 | 40.70 |
| June'20 | 44.487 | 61.79 | 20.341 | 28.25 | 22.196 | 30.83 |
| July'20 | 46.918 | 65.16 | 21.216 | 29.47 | 23.592 | 32.77 |
| Aug'20 | 55.330 | 76.85 | 25.455 | 35.35 | 27.531 | 38.24 |
| Total | 555.791 | 72.074 | 254.395 | 32.456 | 283.680 | 36.66 |

In the 136th PSOC meeting Southco stated that Dasmantpur feeder in expected to be charged today i.e. on 21.08.2019.

Sr.GM (O&M), Zone –I suggested to explore the following link lines for providing adequate matching load in Machhakund system.

- i. Connecting Patangi S/S or Proposed Lamtaput S/S with Podagada S/S through 132 kV link.
- ii. Providing Sunabeda S/S area load in Machhakund system
- iii. Modification of Jayanagar S/S to accommodate Jayanagar load

In the 137th PSOC meeting, SOUTHCO stated that 33 kV Dasmantpur feeder did not stand after charging. Insulators are being changed by the contractor. Sr. GM (Const) stated that 132 kV Patangi-Podagada line is under construction and expected by March'2020. He also suggested to utilize 132 kV NALCO-Sunabeda line to feed Sunabeda area load from Machhakund system by bus splitting.

In the 139th PSOC meeting SOUTHCO stated that insulator changing of Dasmantpur feeder is under progress. It was suggested that GRIDCO may convene a meeting with PMU for early restoration of the feeder, so that, more matching load can be provided in Machhakund system. SLDC may write to PMU to ascertain the status of feeders at Podagada S/S.

In the 140th PSOC meeting SOUTHCO stated that about 10 Nos of span have left for insulator changing. CGM (O&M) suggested to connect 33kV Medical feeder may with Podagada S/S for increase load at Machhakund system. Patangi –Podagada 132 kV connectivity is expected by March'19, by which, more load can be kept in Machhakund system. Further Rly. is requesting to change the connectivity of Rayagada Traction feeder from Rayagada to Theruvali S/S. GRIDCO has agreed to convene a meeting with PMU to discuss the issue.

In the 141th PSOC meeting GRIDCO has agreed to convene a meeting with PMU during the month of February'20 to discuss the issue. CGM (O&M) suggested that Kakariguma feeder may be added to Podagada S/S.

GRIDCO / O&M/SLDC/SOUTHCO may deliberate.

H. Under Frequency Relay operation in OPTCL System during the month of August'20.

Since, the frequency had never gone beyond the lowest setting of UFR, there was no UF Relay operation occurred during the month of **August'20**.

Members may note

I. Status of Open Access applications up to the month of August 2020

The status of different types of Open Access applications received and disposed by SLDC is as tabled.

| Sl. No | Month | No of Applications received | | | | | No of Applications Disposed | | | | | No of App. Rejected | MU |
|--------|--------------|-----------------------------|-------------|--------|-------|---------------|-----------------------------|-----------|-------|--------|-----|---------------------|---------|
| | | Intra - State | Inter-State | | Total | Intra - State | Inter-State | | Total | | | | |
| | | | Bilateral | | | | PX | Bilateral | | | | | |
| | | | ST | MT/ LT | | | | ST | | MT/ LT | | | |
| 1 | April'20 | 39 | 36 | 0 | 32 | 107 | 39 | 36 | 0 | 32 | 107 | 0 | 581.09 |
| 2 | May'20 | 68 | 56 | 0 | 34 | 158 | 68 | 56 | 0 | 34 | 158 | 0 | 858.52 |
| 3 | June'20 | 106 | 19 | 0 | 56 | 181 | 106 | 19 | 0 | 56 | 181 | 0 | 612.13 |
| 4 | July'20 | 69 | 34 | 0 | 40 | 143 | 69 | 34 | 0 | 40 | 143 | 0 | 727.35 |
| 5 | Aug'20 | 130 | 37 | 1 | 41 | 209 | 130 | 37 | 1 | 41 | 209 | 0 | 701.02 |
| | Total | 412 | 182 | 1 | 203 | 798 | 412 | 182 | 1 | 203 | 798 | 0 | 3480.11 |

PART C – Issues discussed in the earlier OCC meetings of ERPC

C.1: Testing of primary frequency response of state generating units by third party agency-- ERLDC

The Hon'ble Central Electricity Regulatory Commission (CERC), vide notification dated 12th April 2017, had notified Indian Electricity Grid Code (Fifth Amendment) Regulations, 2017. As per this notification, following proviso has been added at the end of Regulation 5.2 (g) of Part 5 of the Principal Indian Electricity Grid Code (IEGC) Regulations: *"Provided that periodic check-ups by third party should be conducted at regular interval once in two years through independent agencies selected by RLDCs or SLDCs as the case may be. The cost of such tests shall be recovered by the RLDCs or SLDCs from the Generators. If deemed necessary by RLDCs/SLDCs, the test may be conducted more than once in two years."* In compliance of IEGC, process of testing of primary frequency response of regional generating units (eligible for RGMO as per IEGC section 5.2 (f)) has been started by POSOCO. All the SLDCs are requested to share their action plan for testing of primary frequency response of the generating units.

SLDC, OHPC & OPGC may deliberate

C.2: Monthly Data on Category-wise consumption of electricity in States/UTs--- CEA

1. CEA vide mail informed that Hon'ble MoSP(IC) has desired the month-wise category-wise consumption data in the various States/UTs from April,2019 to July, 2020. CEA requested all the concerned utilities of States to furnish the data at the earliest. All the concerned utilities of States may furnish the data.

2. CEA also informed that Hon'ble MoSP(IC) has also desired to know the reasons for the use of captive power plants by Industrial Consumers despite availability of adequate power in the country.

SLDC & DISCOMs may deliberate

C.3: Data for preparation Load Generation Balance Report (LGBR) of ER for the year 2021-22

As per the IEGC, RPC Secretariat is responsible for finalization of the Annual Load Generation Balance Report (LGBR) for Peak as well as Off-peak scenarios and the annual outage plan for the respective region. To facilitate the preparation of LGBR of Eastern Region by ERPC Secretariat within the schedule period, the following data/information for

(a) Balance period of current Financial Year 2020-2021 with effect from October' 2020 to March' 2021 and (b) Financial Year 2021-2022 (April 2021 to March 2022) in respect of the constituents/utilities of Eastern Region is urgently required:.

- i) The unit wise and station wise monthly energy generation proposed from existing units during (a) Balance period of current Financial Year 2020-2021 with effect from October' 2020 to March' 2021 and (b) Financial Year 2021-2022.
- ii) Annual maintenance program for each of the generating units (thermal and hydro both).
- iii) Generating units under R&M / long outage indicating date of outage and reasons of outage and expected date of return (thermal and hydro both).
- iv) Partial and forced outage figures (in %) of generating units for the last 3 years.
- v) Month wise peak demand (MW) – restricted and unrestricted peak demand.
- vi) Month wise off-peak demand (MW).
- vii) Month wise energy requirement (in MU).
- viii) Month wise & source wise power (both MU & MW) purchase and/or sale plan.
- ix) Schedule of commissioning of new generating units during (a) current Financial Year 2020-2021 with effect from October' 2020 to March' 2021, (b) Financial Year 2021-22 and unit-wise monthly generation program (in MU).
- x) Allocation of power from new generating units.
- xi) Month wise and annual planned outage of transmission system (Transmission lines 220kV and above / ICTs / Reactors/ other elements during (a) current Financial Year 2020-2021 with effect from October' 2020 to March' 2021 and (b) Financial Year 2021-22.

Information may please also be submitted in the form of soft copy through email (mail ID: sldcgridco@yahoo.com / cld_sldc@sldcorissa.org.in).

Members may furnish the above data.

C.4: Nomination of nodal persons for communication related to tripping of grid elements, primary frequency response observed at generating stations and Mock Black Start exercise

For analysis of tripping incident of any grid elements and primary frequency response of generating units in Odisha Power System, high resolution data from various generating stations is required. Also to plan and carry out mock black start exercise, co-ordination between executives of SLDC and OHPC is essential. For smooth communication regarding transfer of data and co-ordination, all the generating stations are requested to nominate at least one officer as nodal person for tripping analysis of any grid element and for primary frequency response analysis of generating units as well as to carry out mock black start exercise. Name, contact number and email address of nominated person may be shared.

OHPC/IBTPS may deliberate

C.5: 220 kV Inter-connecting lines of OPTCL with 400/220 kV Bolangir(PG), Keonjhar & Pandiabil S/s

In 141th PSOC meeting the status has been updated as follows:

| Sl. | Name of the transmission line | Completion schedule |
|-----------|---|---|
| 1. | 2 X 315MVA 400/220kV Bolangir S/s | |
| a. | LILO of one circuit of Sadeipalli-Kesinga 220 kV D/C line at Bolangir (PG) S/S. | Construction of 220 kV Sadeipali- Kesinga line has started. |
| 2. | 400/220 kV Keonjhar S/S. | |
| a. | Keonjhar (PG)-Turumunga (220/132 kV) & 220 kV D/C Line. | By 2021. Order placed. |
| 3. | 400/220 kV Pandiabil Grid S/s | |
| a. | Pratapsasan(OPTCL)-Pandiabil (PG) 220 kV D/C | June'2020 |

C.GM (Cont) / CGM (Telecom) may update.

C.6: Update on status of telemetry

CERC vide order dated 28.02.2016 on Petition No. 007/SN/2014 directed NLDC and respective RLDCs to update the status of telemetry every month at their respective websites and take up the issue of persistent non-availability of data from Generating Stations/substations at RPC meetings for appropriate action. Major issues are given below:

xxxxxxx

Issues relating OPTCL Network:

Narsingpur data:

In the 132nd PSOC meeting CGM (Telecom) stated that survey work for Meramundali-Bhanjanagar line is under process. OPGW will be reached at site after completion of survey and preparation of drum schedule.

In the 134th meeting CGM (Telecom) stated that delivery of OPGW has already been started.

In the 135th PSOC meeting DGM (Telecom) stated that replacement of earth wire by OPGW in 220 kV Bhanjanagar-Meramundali is expected by December'2019

NALCO data: DGM (Telecom) stated that the vender list and rate will be provided to NALCO for placement of order by them.

In the 137th PSOC meeting, NALCO stated that the estimate has already been received from OPTCL (Telecom). Approval from higher authority in under process.

In the 139th PSOC meeting, NALCO stated that they need protection scheme to be incorporated in the estimate. PSOC advised NALCO to write Telecom wing of OPTCL for revise estimate.

In the 140th PSOC meeting, DGM (Telecom) stated that protection scheme has already been incorporated in the estimate. NALCO representative was not present in the meeting for deliberation.

In the 141th PSOC meeting, NALCO stated that the file is under process by their Finance wing.

Telecom / NALCO may deliberate the status

C.7: Mock Black start exercises in Eastern Region – ERLDC

Schedule and tentative date for conducting mock black start exercise in OHPC stations is as tabled.

| Sl. | Name of Hydro Station | Schedule | Tentative Date | Schedule | Tentative Date |
|-----|-----------------------|--------------------------|-------------------------------------|----------------------------|------------------|
| | | Test-I | | Test-II | |
| 1 | Upper Kolab | Last week of May-2019 | Done on 19 th July19 | Last week of January 2020 | |
| 3 | Rengali | 2nd week of June 2019 | Done on June'19 | Last week of November 2019 | Done on 07.03.20 |
| 4 | U.Indravati | 3rd week of June 2019 | Done on June'19 | 2nd week of February 2020 | |
| 6 | Balimela | 3rd week of October 2019 | Done on 17 th July19 | 1st week of March 2020 | Done on 12.02.20 |
| 9 | Burla | Last week of June 2019 | Done on 20 th July' 2019 | Last week of February 2020 | Done on 11.02.20 |

SLDC / O&M/ OHPC may deliberate

C.08: Monitoring of Next Six-Month New Element Integration in OCC and Its Update on Monthly Basis --ERLDC

It has been observed that many elements are getting interconnected into the system and beforehand details are not available with the system operator resulting in difficulty in carrying our operational planning activity. In view of this, as a regular agenda all ISTS and ISGS/IPP to update the OCC regarding any new elements at 220 kV and above which will be integrated in

next six month with the grid. For State Grid, SLDC will be submitting the details on behalf of its intrastate Generation and transmission system. The format is given below:

| Transmission Elements | Agency/ Owner | Scheme (ERSS/ TBCB/ Standing Committee/State | Schedule Completion | Projected Month for Completion | Issue Being Faced |
|-----------------------|---------------|--|---------------------|--------------------------------|-------------------|
| | | | | | |

In previous several OCC, Transmission licensees and SLDCs are requested to submit RLDC/RPC following details on monthly basis

- List of transmission element /generators of State and ISTS licensees synchronised in the last month.
- List of transmission element /generators expected to be synchronised during next month or in near future

Some SLDCs are submitting the list of intrastate and interstate line on regular basis, however transmission element /generators expected to be synchronised during next month or in near future is not submitted by any SLSC/Transmission licensee to RLDC/RPC.

In 163rd OCC, OCC advised all the constituents, SLDCs and ISTS licensees to submit the details to erldcprotection@posoco.co.in as per the format.

List of upcoming Transmission Element is received from Bihar and Jharkhand.

In the 141th PSOC meeting, DGM (Const) stated that the information has already been submitted.

CGM (O&M) / C.G.M. (const.) may deliberate.

C.9: Preparation of crisis management plan for Cyber Security in Power Sector in line with CERT-IN.

The activity of the preparation of Crisis Management Plan for countering the cyber-attacks and its implementation including the Mock Drills, audits etc. is being monitored by CEA regularly in line with crisis management plant of Ministry of Power. Power Utilities (including generation, transmission & distribution utilities) of eastern region are to furnish regularly the updated status to on the same to Chief Engineer, Distribution Planning & Development Division, CEA.

In 142nd OCC, ERLDC informed that, in line with Enquiry Committee Recommendation, cyber security audit is being conducted on regular basis for SCADA system installed at ERLDC and SLDC as well but cyber security audit for telecom infrastructure installed in Eastern Region is not being carried out.

OCC advised all the constituents to conduct the cyber security audit on telecom infrastructure installed in Eastern Region. It is further advised that compliance / mitigation of the points observed during the audit should also be completed for improvement of the telecom infrastructure in ER.

As suggested by CEA, a format has been circulated among ER constituents for furnishing the information of the respective systems for discussion in OCC Meeting. The format is enclosed at Annexure-E1.

OCC advised all the constituents to submit the information to ERPC as per Annexure-E1. OPTCL has submitted the required data

In the 139th PSOC meeting, IT stated that the Auditing is under process since 20th Nov'19 and will be completed today. The information has been submitted to ERPC in the prescribed format.

In the 140th PSOC meeting, SLDC stated that IT wing have forwarded the report in the prescribed format to ERPC for the Qr. ending Sept'2019.

In the 141th PSOC meeting IT stated that ISO certification for cyber security has been renewed for one year. Telecom may provide 3 Nos. CCTV, Fire alarm and biometric arrangement for their server room.

Sr. G.M (IT) /Telecom may update.

PART-D – Operational Issues

D.1: Non-compliance of drawal schedule by DISCOMs

Non-compliance of drawal schedule messages issued to Discoms during the month of **August’20:**

| Sl. No | Name of Discom | No. of message issued | Over drawal (MU) | Deviation (%) |
|---------------|-----------------------|------------------------------|-------------------------|----------------------|
| 1 | CESU | 0 | 9.850 | 1.27 |
| 2 | WESCO | 0 | -5.538 | 0.86 |
| 3 | NESCO | 0 | 6.123 | 1.41 |
| 4 | SOUTHCO | 0 | -1.681 | 0.53 |
| | Total | 0 | 8.753 | 1.27 |

It is noticed that all the DISCOMs have maintained their drawal as per the schedule. Daily drawal profile of all DISCOMs is as indicated in the presentation.

SLDC/ Discoms may deliberate.

D.2: Compliance of CEA Regulations for Grid Connectivity of Renewable Energy Sources.

As per CEA (Technical Standards for connectivity to Grid) Regulations, 2007, dated 21st February 2007, the pertinent clauses 6 (iii) & 6 (iv) (b) of general Connectivity Conditions shall be applicable to all the Generating Projects including the renewable, which are getting connected to the Grid at voltage level of 33kV & above. Subsequently, CEA have notified the CEA (Technical Standards for Connectivity of the Distributed Generation Resources) Regulations 2013 dated 30.09.2013. These Regulations are applicable for “Distributed Generation Resources”, which means A Generating Station feeding electricity into the System at voltage level below 33kV. Needless to mention that these Regulations also cover the renewable projects connected to the Distribution Licensee’s System at voltage level of below 33kV. The letter received from CEA is annexed herewith.

SLDC has already forwarded the Regulations & a letter received from DoE, Govt. of Odisha to the Distribution Licensees.

A meeting has been convened by Gridco in this regard with the RE generators, OPTCL, Telecom & SLDC. In the meeting, two nos of agencies presented their data acquisition logic from the RE sources. It was decided that each agency will take up a pilot project for data communication from one RE source to SLDC. On completion of the above project next course of application shall be decided.

A committee has been constituted with representatives of GRIDCO, O&M, Telecom & SLDC. This issue was also discussed in the 16th GCC meeting held on 09.08.2019. GRIDCO assured to make a demo of data communication from MGM Solar at Tangi to SLDC by end of August’19.

After successful demonstration of the data communication from the pilot Solar plant by Chemtrol, A meeting was convened by GRIDCO with all the Solar developers, Telecom, SLDC, OPTCL & DISCOMs to discuss the commercial issue.

In the 140th PSOC meeting GRIDCO stated that the rate offered by M/s Chemtrol for integration of real time solar data is being examined by the developers. The next meeting is scheduled to be held on 27th December’19 to discuss and finalize the issue.

In the 141th PSOC meeting GRIDCO stated that 15th January'20 was the dead line fixed for placing order by the developers. Data communication is expected by end of March'2020.

GRIDCO may deliberate the status.

D.3: Data communication from newly commissioned RE sources connected at 132 kV- SLDC

There are as many 8 Nos. of Solar projects with installed capacity of 272.5 MW have connected with OPTCL network through 132 kV lines. The real time data of these plants are yet to be received at SLDC control room. Since the generation quantum is quite substantial (to the tune of 0.6 MU during a day), this has an impact on real time generation monitoring.

In the 133rd PSOC meeting CGM (Telecom) stated that Vinto Solar data can be integrated only after laying of optical fiber, which has been proposed for PSDF funding

In the 137th PSOC meeting CGM (Telecom) stated that laying of optical fiber is expected to be completed by December'2019. DGM (Telecom) suggested that SLDC may write a letter to Vento Power (Solar) at Kesinga to explore the data communication, since all communication equipment are available with them. Data communication can be made through after visit of the service Engineer of the company.

In the 138th PSOC meeting, it was suggested that Telecom may ensure establishment of data communication facility before recommending for connectivity for any Solar Plant.

In the 139th PSOC meeting Telecom stated that data communication from all the Solar stations connected through 132 kV is expected by January'2020.

In the 140th PSOC meeting, DGM (Telecom) stated that the Despatch Instruction for OPGW has already been issued. Laying of optical fiber is expected by June'20. As suggested by DGM (Telecom), SLDC may write a letter to Vento Power (Solar) at Kesinga to explore the data communication, since all communication equipment are available with them.

In the 141th PSOC meeting DGM (Telecom) stated that Vento Solar at Kesinga has procured PLC in place of RTU resulting non- communication of data. It was decided that GRIDCO shall approach all the RE projects to speed up the process of data communication. Telecom may explore the process for laying of optical fiber.

SLDC /Telecom may deliberate the status.

D.4: Despatch Scheduling for RE Generation.

At present about 19 Nos of RE generating plants having 340 MW installed capacity operating in the State. None of the plants are furnishing day ahead schedule except 2-3 Nos. In absence of day ahead Declared injection Schedule, there is a substantial mismatch of day ahead generation planning. Also SLDC is not aware of the PPA made by GRIDCO with the Solar plants. As such, it is requested that GRIDCO may forward the copy PPA made with the Solar plants and insist the plants to submit day ahead DC in respect of their plants to SLDC in 15 minute blocks.

In the 139th PSOC meeting GRIDCO assured to forward the PPAs before next PSOC meeting also to write all the Solar stations to submit day ahead injection schedule to SLDC. The said documents are yet to be received by SLDC.

In the 140th PSOC meeting, SLDC stated that the PPAs made by GRIDCO with Solar plants have been received by SLDC. GRIDCO was requested to ask the Solar plants to forward their day-ahead generation schedule to SLDC.

In the 141th PSOC meeting it was decided that GRIDCO shall convene a meeting with solar developer to discuss the issue of day ahead scheduling of solar power injection.

GRIDCO may deliberate the status.

D.5: Implementation of Automatic Meter Reading for OPTCL-Discom interface points.

In the 116th PSOC meeting, IT stated that out of 840 nos. of meters integrated, around data from 750 nos. of meters will be received each month. Data from the remaining 90 meters are to be collected manually.

In the 138th PSOC meeting IT stated that software development is under progress and expected to be completed for CESU area energy meters.

In the 139th PSOC meeting IT stated that M/S TCS has assured to extract 90% of meter data from CESU & SOUTHCO interface meters.

In the 140th PSOC meeting IT stated that the discrepancies have been intimated to M/s TCS. As per TCS report, they are not able to extract meter data on 1st day of the month due to removal of optical fiber link from the meter for data downloading.

IT / SLDC/ GRIDCO may update the status

D.6: Energy Accounting of Hydro & RE Generators.

As per the regulatory provisions, energy accounting of all the generators in a control area has to be carried out by the concerned SLDC. So SLDC proposes to compute the energy accounting of all the hydro generators and RE sources from October'2020.

GRIDCO/ SLDC may discuss.

D.7. Replacement/Rectification of Billing meters

It is observed that some billing meters used for energy accounting purpose are defective and the information regarding these meters has already been shared with O & M.

SLDC/O&M may deliberate

D.8: Utilization of 132 kV LILO line for Kalarangi S/S as 33 kV feeder

TPCODL is utilizing a part of 132 kV LILO line for Kalarangi S/S as 33 kV feeder, resulting in Goda S/s being connected through "T" arrangement with 132 kV Kamakhya Nagar-Duburi (Old) line. TPCODL may make the line free to complete the LILO arrangement. This issue had been discussed several times in earlier meetings and TPCODL (erstwhile CESU) had assured to make the said 132 kV line free.

TPCODL/ CGM (Const) may deliberate

D.9: 220kV Balimela-Upper Sileru line Status:

Long since the 220 kV Balimela-Upper sileru line is remaining in idle charged condition from Sileru end. Members may discuss how best to utilize the line.

GRIDCO/ O&M /SLDC may deliberate

PART E: OPERATIONAL PLANNING

E.1: Commissioning status of new Transmission elements.

The status of commissioning of new transmission elements deliberated in the last meeting is as follows:

| Sl. No | Name of the Project | Expected month of Charging | DISCOM | 33kV Take off Planning by DISCOMs (4 Nos. Feeder Bay) |
|--------|---|----------------------------|--------------|--|
| 1 | 220 kV Jayanagar-Jeypore(PG) 2nd DC line | | | |
| 2 | 132/33kV CDA (Brajabiharipur) Cuttack S/s | Oct-20 | TPCODL | |
| 3 | 132/33kV Pratapsasan S/s | Oct-20 | TPCODL | |
| 4 | 132/33kV Gandia S/s | Feb-21 | TPCODL | |
| 5 | 132/33kV Rajnagar S/s | Mar-21 | TPCODL | |
| 6 | 220/33kV Telkoi S/s | Dec-20 | TPCODL/NESCO | |
| 7 | 132/33kV Maneswar S/s | Oct-20 | WESCO | |
| 8 | 220/33kV Deogarh S/s | Nov-20 | WESCO | |
| 9 | 132/33kV Bhatli S/s | Dec-20 | WESCO | |
| 10 | 132/33kV Hirakud S/s | Feb-21 | WESCO | |
| 11 | 132/33kV Birmaharajpur S/s | Mar-21 | WESCO | |
| 12 | 132/33kV Thuapalli S/s | Mar-21 | WESCO | |
| 13 | 132/33kV R Udayagiri S/s | Oct-20 | SOUTHCO | |
| 14 | 220/33kV Govindpalli S/s | Oct-20 | SOUTHCO | |
| 15 | 132/33kV G Udayagiri S/s | Dec-20 | SOUTHCO | |
| 16 | 220/132/33kV Gunupur S/s | Jan-21 | SOUTHCO | |
| 17 | 132/33kV Nawrangpur S/s | Feb-21 | SOUTHCO | |
| 18 | 132/33kV Boriguma S/s | Mar-21 | SOUTHCO | |

The status of 33 kV bays and takeoff arrangement by DISCOMs are as tabled

| Sl no | Name of Project | DISCOM | Voltage | Date of Charging | Bays Available | Bays utilised by DISCOMs | Bays Available for utilisation by DISCOMs | Utilization in % |
|-------|-----------------|--------|------------|------------------|----------------|--------------------------|---|------------------|
| 1 | Konark | TPCODL | 132/33 | 29-06-2015 | 4 | 1 | 3 | 25% |
| 2 | Samagara | TPCODL | 220/132/33 | 14-07-2015 | 5 | 2 | 3 | 40% |
| 3 | Marshaghai | TPCODL | 132/33 | 16-10-2015 | 5 | 2 | 3 | 40% |
| 4 | Atri | TPCODL | 220/132/33 | 24-02-2016 | 4 | 0 | 4 | 0% |
| 5 | Mania | TPCODL | 132/33 | 31-03-2016 | 5 | 2 | 3 | 40% |
| 6 | Infocity-II | TPCODL | 220/33 | 23-12-2016 | 6 | 3 | 3 | 50% |

| | | | | | | | | |
|-------|--------------|---------|--------------|------------|-----|----|-----|------|
| 7 | Chandaka - B | TPCODL | 220/132/33 | 28-03-2017 | 4 | 0 | 4 | 0% |
| 8 | Khajuriakata | TPCODL | 132/33 | 28-03-2017 | 5 | 2 | 3 | 40% |
| 9 | Tirtol | TPCODL | 132/33 | 05-01-2018 | 5 | 2 | 3 | 40% |
| 10 | Dhenkikote | TPCODL | 132/33kV | 24.02.2018 | 5 | 2 | 3 | 40% |
| 11 | Khuntuni | TPCODL | 132/33 | 31-05-2018 | 5 | 2 | 3 | 40% |
| 12 | Narasinghpur | TPCODL | 220/33 | 24-08-2018 | 5 | 3 | 2 | 60% |
| 13 | Unit-8 | TPCODL | 132/33 | 01-04-2019 | 5 | 3 | 2 | 60% |
| 14 | Kharagprasad | TPCODL | 132/33kV | 31.07.2019 | 1 | 0 | 1 | 0% |
| 15 | Mancheswar B | TPCODL | 132/33kV | 28.02.2020 | 5 | 0 | 5 | 0% |
| 16 | Goda | TPCODL | 220/132/33kV | 29.05.2020 | 5 | 0 | 5 | 0% |
| 17 | Satasankha | TPCODL | 132/33kV | 25.06.2020 | 5 | 0 | 5 | 0% |
| 18 | Malkangiri | Southco | 220/33 | 27-03-2017 | 4 | 2 | 2 | 50% |
| 19 | Muniguda | Southco | 132/33 | 29-11-2017 | 4 | 0 | 4 | 0% |
| 20 | Podagada | Southco | 132/33 | 09-02-2018 | 4 | 2 | 2 | 50% |
| 21 | Chikiti | Southco | 132/33 | 25-02-2019 | 5 | 2 | 3 | 40% |
| 22 | Aska New | Southco | 220/132/33 | 31-03-2019 | 5 | 1 | 4 | 20% |
| 23 | Kasipur | Southco | 220/33 | 30-06-2019 | 4 | 1 | 3 | 25% |
| 24 | Patangi | Southco | 132/33 | 15-09-2019 | 4 | 2 | 2 | 50% |
| 25 | Bangiriposi | Nesco | 132/33 | 03-10-2016 | 4 | 2 | 2 | 50% |
| 26 | Bhogarai | Nesco | 132/33 | 28-03-2017 | 4 | 1 | 3 | 25% |
| 27 | Udala | Nesco | 132/33 | 16-09-2018 | 5 | 3 | 2 | 60% |
| 28 | Keonjhar | Nesco | 220/33 | 31-12-2018 | 5 | 2 | 3 | 40% |
| 29 | Chandbali | Nesco | 132/33 | 20-02-2019 | 4 | 1 | 3 | 25% |
| 30 | Betanati | Nesco | 132/33 | 19-04-2019 | 4 | 2 | 2 | 50% |
| 31 | Agarpada | Nesco | 132/33 | 30-08-2019 | 5 | 1 | 4 | 20% |
| 32 | Jayapatana | Wesco | 220/132/33 | 11-07-2019 | 4 | 2 | 2 | 50% |
| 33 | Kantabanji | Wesco | 132/33 | 28-02-2018 | 5 | 2 | 3 | 40% |
| 34 | Baragarh New | Wesco | 220/132/33 | 21-03-2018 | 1 | 0 | 1 | 0% |
| 35 | Ghens | Wesco | 132/33 | 13-04-2018 | 4 | 4 | 0 | 100% |
| TOTAL | | | | | 154 | 54 | 100 | 35% |

In the 140th PSOC meeting AGM (Const.) stated that 2 Nos. 40 MVA Transformers have been provided in the proposed Maneswar S/S. WESCO may divert all loads from Chipilima PH S/S to Maneswar S/S to make free the Chipilima PH S/S. SLDC suggested to instruct and impart training the executives deployed at the newly charged S/Ss for extraction of the meter data and forward to SLDC. DGM (Const.) suggested that SLDC may write a letter to CGM (Const.) in this regard

In the 141th PSOC meeting WESCO stated that due to shortage of funds they cannot construct 33 kV line. It was suggested that CGM (Const) may convene a meeting to review the take-off arrangement.

CGM (Construction) / DISCOMs may deliberate

E.2: Major Events in the month of August'20

1. On Dt. 06.08.20 at 17:20 Hrs -Unit #1(8MW) of BPPPL (Baitarani Power Project Pvt Ltd) synchronized with the Grid (M/s BPPPL connected to Grid S/S Anandpur through 132 kV SC Line).
2. On Dt. 06.08.20 at 19:21 Hrs- 315 MVA, 400/220 kV ICT-II at Tata Steel Ltd, Kalinganagar S/S charged.
3. On Dt. 07.08.20 at 13:37 Hrs -Unit #2(8MW) of BPPPL (Baitarani Power Project Pvt Ltd) synchronized with the Grid (M/s BPPPL connected to Grid S/S Anandpur through 132 kV SC Line).
4. On Dt. 07.08.20 at 16:27 Hrs- 315 MVA, 400/220 kV ICT-I at Tata Steel Ltd, Kalinganagar S/S charged.
5. On Dt. 14.08.20 at 13:24 Hrs - 40 MVA, 132/33 kV Power Transformer- II charged at Grid S/S, New Bargarh.
6. On Dt. 15.08.20 at 01:09 Hrs - 132 kV Tusura-Deogaon RTSS charged.
7. On dt. 21.08.20 at 00:25 Hrs: - Unit #3(8MW) of BPPPL (Baitarani Power Project Pvt Ltd) synchronised with the Grid (M/s BPPPL connected to Grid S/S Anandpur through 132 kV SC Line).

Members may note

E.3: Important Grid Incidences during the month of August'20.

On Dtd. 03.08.2020 at 16:17 Hrs, 220kV Rengali switchyard (OPTCL)- Tarkera S/C tripped due to B Phase to Earth fault. At 16:58Hrs, 220kV Rengali switchyard (OPTCL)- Barkote S/C tripped due R & Y Phase fault. At 17:17 Hrs, 220kV Rengali switchyard (OPTCL)- Rengali (PG) Ckt-2 tripped due to Y & B phase fault. At 17:35 Hrs, 220kV Rengali switchyard (OPTCL)- Rengali (PG) Ckt-1 tripped due to B phase fault. At the same time 220kV TSTPP- Rengali P.H. S/C tripped from TSTPP end resulting in complete power failure at 220kV Rengali switchyard (OPTCL) and at 220kV Rengali PH. All running units at Rengali P.H. tripped due to loss of evacuation path.

O&M may discuss

E.4: Outage of major transmission Elements during the month of August'20. (above 10 hrs).

| SI No | Transmission line / element | Tripping Dt/time | Restoration Dt/time | Reason |
|-------|---|-------------------|---------------------|--|
| 1 | 132kv Lapanga-Jharsuguda feeder | 02.08.20 00:33 | 03.08.20 15:13 | Due to snapped jumper |
| 2 | 132KV Nuapatna-Khajuriakata-Denkhanal 'T' line. | 02.08.20 22:43 | 03.08.20 09:43 | Distance relay tripped, zone 2, 46.06kms |
| 3 | 220kV Atri-Narendrapur Ckt-II | 13.08.20 15:36 | 14.08.20 17:14 | B Phase insulator damaged at Loc No-428. |
| 4 | 220 kV Tarkera-Bonai Feeder | 15.08.20 16:39 | 16.08.20 12:22 | R Phase Suspension Insulator damaged at Loc. 610. |
| 5 | 220/132kV 100 MVA Auto Tfr- I at Tarkera | 20.08.20 18:02 | 21.08.20 09:56 | Tripped on Buccholz Relay |
| 6 | 132KV Balasore-Udala feeder | 26.08.20 17:15 | 27.08.20 13:58 | Suspension insulator string punctured at Loc no-76 (R & Y) and 77 (R, Y & B). |

O&M may discuss

E.5: Prolonged outage of Transmission elements

| Sl No | Transmission line / element | Date of outage | Reason | Expected date of restoration |
|-------|---|----------------|---|--|
| 1 | 220 kV Samangara - Pandiabil ckt -I &II | 03.05.2019 | Tower Collapsed during cyclone FANI | Project handed over to PGCIL |
| 2 | 400 kV New Duburi Meramundali ckt- I & II | 19.03.2020 | Multiple towers collapsed at loc no 17,18 & 19 | Expected to be charged by Sept- 2020. |
| 3 | 100 MVA Auto-II at Grid S/S, Duburi | 08.03.2020 | Tripped on Buchholz alarm and differential protection. | Problem in tertiary winding as per E&MR wing. |
| 4 | 132 kV Chandaka -BPPL feeder | 11.07.2020 | Erection & Commissioning of 4 Nos of PA type interposing towers in view of low ground clearance | Work in progress. Expected to be charged in the 2nd week of September- 2020. |

O&M may discuss

E.6: Review of Outage Program of State Generators for the month of October'20:

Tentative Outage programme for State Generators for the month of **October'20**

| Sl. | Station | Unit | Period | Remarks |
|-----|----------|--------------------------|--|---|
| 1 | Burla | # 1 # 5 # 6 # 7 | 14.03.18 to continue 25.10.16 to continue 16.10.15 to continue 06.12.19 to continue | T&G cover water leakage Under R, M & U Under R, M & U Annual Maintenance |
| 2 | Balimela | # 1 # 2 # 4 | 05.08.16 to continue 20.11.17 to continue 02.03.20 to continue | Under R&M Under R&M Problem in PMG |
| 4 | U. Kolab | # 3 | 07.01.20 to continue | Generator Bearing Temp. High |

OHPC may deliberate

E.7: Generation Program for the month of October'20.

Generation schedule for the month of October'20 furnished by OHPC are given below.

| Name of Hydro Gen. Station | Generation Program (MW) | | Reservoir Level as on 01.09.2020 | Reservoir Level as on 01.09.2019 | MDDL | High Flood Reservoir Level |
|----------------------------|------------------------------------|------------------------------------|----------------------------------|----------------------------------|------------|----------------------------|
| | Oct'20 (1 st fortnight) | Oct'20 (2 nd fortnight) | | | | |
| HPS-I, Burla | 100 | 100 | 625.91 ft. | 622.93 ft. | 590 ft. | 630 ft. |
| HPS-II, Chiplima | 50 | 50 | | | - | - |
| Balimela | 300 | 300 | 1496.5 ft. | 1491.70 ft. | 1440 ft. | 1516 ft. |
| Rengali | 240 | 240 | 123.8 mtr. | 122.08 mtr. | 109.72 mtr | 123.5 mtr. |
| U.Kolab | 100 | 100 | 850.54 mtr. | 853.43 mtr. | 844 mtr | 858 mtr. |
| U. Indravati | 350 | 350 | 636.86 mtr. | 640.38 mtr. | 625 mtr | 642 mtr |
| MKD (O/D) | 40 | 40 | 2739.2 ft. | 2745.85 ft. | 2685 ft. | 2750 ft. |
| TOTAL | 1180 | 1180 | | | | |

Generation schedule may change depending on inflow & availability of machine.

SLDC / OHPC may deliberate

E.8: Anticipated power generation and demand for the month of October'20.

| Sl. No | Discom | Average | Peak |
|---------------------|-------------------------------------|-------------|-------------|
| 1 | CESU | 1100 | 1300 |
| 2 | WESCO | 1030 | 1150 |
| 3 | NESCO | 800 | 950 |
| 4 | SOUTHCO | 470 | 550 |
| 5 | Total Discom | 3400 | 3950 |
| | System Loss & others | 100 | 150 |
| | Total Demand | 3500 | 4100 |
| Availability | | | |
| 1 | Hydro | 1180 | 1350 |
| 2 | State Thermal | 910 | 910 |
| 3 | IPP, small hydro &RE | 820 | 780 |
| 4 | ISGS share (including OA& purchase) | 900 | 1000 |
| 5 | CGP support (OA) | 300 | 300 |
| 6 | Total availability | 4110 | 4340 |
| 7 | Surplus / Deficit | 610 | 240 |

Members may discuss.

PART F: OTHER ISSUES

F.1: Agenda of NESCO:

- (i) Data suspect for Joda Grid, Jajpur Town Grid, Rairangpur Grid, Bangiriposi-Kalabadia feeder.
- (ii) As RVDU shows suspected data, it is quite unpredictable to know the exact drawl schedule position for that suspected data. Therefore it is requested to reflect the normal loading position for the above suspected data.
- (iii) There is huge difference of 15-22MU between RVDU drawl data and actual drawl data since last two-three months, due to which it is difficult to maintain the minimum deviation at the end of the month.
- (iv) 132/33KV Dhenkikote, 132/33KV Chandabali, 132/33KV Agarpada Grid data are to be incorporated in the RVDU.

Telecom /Nesco may deliberate