

## EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH JUNE -2020

### EXPORT TTC/ATC

SL. No.	Month	Export TTC	Reliability Margin	Counterflow on account of Surrender of LTA(ISGS)	Export ATC	Contingency	Assumptions
1	JUNE-2020	1771 MW	63 MW (2% of load assumed)	0 MW	1708 MW	Outage of one 220kV Jayanagar-Jeypore(PG) Ckt.	Generation: 5006 MW Load: 3148 MW

### IMPORT TTC/ATC

SL. No.	Month	Import TTC	Reliability Margin	Import LTA(ISGS)	Import ATC	Contingency	Assumptions
1	JUNE-2020	3247 MW	98 MW (2% of load assumed)	1200 MW	1949 MW	(i) Outage of one 220kV Tarkera-Rourkela(PG) Ckt. (ii) Outage of OPGC Unit-3 (iii) Outage of VAL (STERLIT) Unit-2	Generation: 1806 MW Load: 4902 MW