

## EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH JANUARY -2021

### EXPORT TTC/ATC

SL. No.	Month	Export TTC	Reliability Margin	Counterflow on account of Surrender of LTA(ISGS)	Export ATC	Contingency	Assumptions
1	JANUARY-2021	1540 MW	47 MW (2% of load assumed)	700 MW	2193 MW	Outage of one 220kV Jayanagar-Jeypore(PG) Ckt.	Generation: 3947 MW Load: 2358 MW

### IMPORT TTC/ATC

SL. No.	Month	Import TTC	Reliability Margin	Import LTA(ISGS)	Import ATC	Contingency	Assumptions
1	JANUARY-2021	2239 MW	73 MW (2% of load assumed)	700 MW	1466 MW	(i) Outage of one 220kV Tarkera-Rourkela(PG) Ckt. (ii) Outage of OPGC Unit- 4 (iii) Outage of VAL (STERLIT) Unit-2 (iv) Outage of GMR Unit-3	Generation: 1532 MW Load: 3651 MW