

## EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH APRIL-2021

### EXPORT TTC/ATC

SL. No.	Month	Export TTC	Reliability Margin	Counterflow on account of Surrender of LTA(ISGS)	Export ATC	Contingency	Assumptions
1	APRIL-2021	1340 MW	61 MW (2% of load assumed)	700 MW	1979 MW	Outage of one 220kV Jayanagar-Jeypore(PG) Ckt.	Generation: 4470 MW Load: 3050 MW

### IMPORT TTC/ATC

SL. No.	Month	Import TTC	Reliability Margin	Import LTA(ISGS)	Import ATC	Contingency	Assumptions
1	APRIL-2021	2167 MW	88 MW (2% of load assumed)	700 MW	1379 MW	(i) Outage of one 220kV Tarkera-Rourkela(PG) Ckt. (ii) Outage of OPGC Unit- 3 & 4 (iii) Outage of VAL (STERLIT) Unit-2	Generation: 2385 MW Load: 4385 MW