

EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH NOVEMBER -2020

EXPORT TTC/ATC

SL. No.	Month	Export TTC	Reliability Margin	Counterflow on account of Surrender of LTA(ISGS)	Export ATC	Contingency	Assumptions
1	NOVEMBER-2020	704 MW	61 MW (2% of load assumed)	500 MW	1143 MW	Outage of one 220kV Jayanagar-Jeypore(PG) Ckt.	Generation: 3832 MW Load: 3053 MW

IMPORT TTC/ATC

SL. No.	Month	Import TTC	Reliability Margin	Import LTA(ISGS)	Import ATC	Contingency	Assumptions
1	NOVEMBER-2020	2221 MW	80 MW (2% of load assumed)	900 MW	1241 MW	(i) Outage of one 220kV Tarkera-Rourkela(PG) Ckt. (ii) Outage of OPGC Unit- 3 (iii) Outage of VAL (STERLIT) Unit-2	Generation: 1911 MW Load: 4000 MW