

EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH AUGUST-2021

EXPORT TTC/ATC

SL. No.	Month	Export TTC	Reliability Margin	Counterflow on account of Surrender of LTA(ISGS)	Export ATC	Contingency	Assumptions
1	AUGUST-2021	1114 MW	65 MW (2% of load assumed)	500 MW	1549 MW	Outage of one 220kV Jayanagar-Jeypore(PG) Ckt.	Generation: 4445 MW Load: 3250 MW

IMPORT TTC/ATC

SL. No.	Month	Import TTC	Reliability Margin	Import LTA(ISGS)	Import ATC	Contingency	Assumptions
1	AUGUST-2021	2767 MW	90 MW (2% of load assumed)	1000 MW	1677 MW	(i) Outage of one 220kV N. Bolangir-Bolangir(PG) Ckt. (ii) Outage of OPGC Unit- 4 (iii) Outage of VAL (STERLIT) Unit-2	Generation: 1906 MW Load: 4500 MW