

EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH SEPTEMBER-2021

EXPORT TTC/ATC

SL. No.	Month	Export TTC	Reliability Margin	Counterflow on account of Surrender of LTA(ISGS)	Export ATC	Contingency	Assumptions
1	SEPTEMBER-2021	1059 MW	62 MW (2% of load assumed)	600 MW	1597 MW	Outage of one 220kV Jayanagar-Jeypore(PG) Ckt.	Generation: 4229 MW Load: 3100 MW

IMPORT TTC/ATC

SL. No.	Month	Import TTC	Reliability Margin	Import LTA(ISGS)	Import ATC	Contingency	Assumptions
1	SEPTEMBER-2021	2372 MW	88 MW (2% of load assumed)	900 MW	1384 MW	(i) Outage of one 220kV Tarkera-Rourkela(PG) Ckt. (ii) Outage of OPGC Unit- 3 (iii) Outage of GKEL Unit-3	Generation: 2166 MW Load: 4385 MW