

## EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH OCTOBER-2021

### EXPORT TTC/ATC

SL. No.	Month	Export TTC	Reliability Margin	Counterflow on account of Surrender of LTA(ISGS)	Export ATC	Contingency	Assumptions
1	Oct-21	1361 MW	60 MW (2% of load assumed)	600 MW	1901 MW	Outage of one 210 MW Generator of IBTPS Stage-I.	Generation: 4425 MW Load: 3000 MW

### IMPORT TTC/ATC

SL. No.	Month	Import TTC	Reliability Margin	Import LTA(ISGS)	Import ATC	Contingency	Assumptions
1	Oct-21	2442 MW	88 MW (2% of load assumed)	900 MW	1454 MW	(i) Outage of one 220kV Tarkera-Rourkela(PG) Ckt. (ii) Outage of OPGC Unit- 3 & 4 (iii) Outage of VAL Unit-2	Generation: 2100 MW Load: 4396 MW