

EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH JANUARY-2022

EXPORT TTC/ATC

SL. No.	Month	Export TTC	Reliability Margin	Counterflow on account of Surrender of LTA(ISGS)	Export ATC	Contingency	Assumptions
1	JANUARY-2022	1090	58MW (2% of load assumed)	350 MW	1382 MW	Outage of OPGC Unit-3	Generation: 4069MW Load: 2910 MW

IMPORT TTC/ATC

SL. No.	Month	Import TTC	Reliability Margin	Import LTA(ISGS)	Import ATC	Contingency	Assumptions
1	JANUARY-2022	2360 MW	104 MW (2% of load assumed)	1200 MW	1056	Outage of one 220kV Tarkera-Rourkela(PG) Ckt.	Generation: 3040MW Load:5198 MW