

## EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH FEBRUARY-2022

### EXPORT TTC/ATC

SL. No.	Month	Export TTC	Reliability Margin	Counterflow on account of Surrender of LTA(ISGS)	Export ATC	Contingency	Assumptions
1	FEBRUARY-2022	1154	59MW (2% of load assumed)	600MW	1695 MW	Outage of one 210MW Generator of IBTPS Stage-1	Generation: 4193MW Load: 2973 MW

### IMPORT TTC/ATC

SL. No.	Month	Import TTC	Reliability Margin	Import LTA(ISGS)	Import ATC	Contingency	Assumptions
1	FEBRUARY-2022	2770	104 MW (2% of load assumed)	800 MW	1866 MW	Outage of one 220kV Tarkera-Rourkela(PG) Ckt.*	Generation: 2593MW Load:5205 MW

\* SPS has been designed for 220kV Tarkera-Rourkela PG line. So, this ckt is not a constraint