

EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH DEC-2024(R-0)

EXPORT TTC/ATC

| SL. No. | Control Area | Month | Export TTC | Reliability Margin | Counterflow on Surrender of ISGS | Export ATC | Contingency | Assumptions |
|---------|--------------|--------|------------|----------------------------|----------------------------------|------------|--|-------------------------------------|
| 1 | Odisha | Dec-24 | 1338 | 68 (2% of load assumed) | 0 | 1270 | Outage of one 210MW Generator of IBTPS Stage-1 | Generation:4801 MW Load: 3400 MW |

IMPORT TTC/ATC

| SL. No. | Control Area | Month | Import TTC | Reliability Margin | Approved GNA | Import ATC | Contingency | Assumptions |
|---------|---------------------------|--------|------------|-----------------------------|--------------|------------|-------------|--------------------------------------|
| 1 | Odisha(excluding Vedanta) | Dec-24 | 2466 | 107 (2% of load assumed) | 2157 | 202 | NIL | Generation: 3039 MW Load: 5364 MW |
| 2 | Vedanta | | 1600 | 32 (2% of load assumed) | NIL | 1568 | | Load: 1600 MW |

Total Import TTC for Odisha Control Area = 2466 MW+ 1600 MW = 4066 MW

* All figures are in MW