

EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH JAN-2025(R-0)

EXPORT TTC/ATC

SL. No.	Control Area	Month	Export TTC	Reliability Margin	Counterflow on Surrender of ISGS	Export ATC	Contingency	Assumptions
1	Odisha	Jan-25	1595	68 (2% of load assumed)	0	1527	Outage of one 210MW Generator of IBTPS Stage-1	Generation:5072 MW Load: 3400 MW

IMPORT TTC/ATC

SL. No.	Control Area	Month	Import TTC	Reliability Margin	Approved GNA	Import ATC	Contingency	Assumptions
1	Odisha(excluding Vedanta)	Jan-25	2394	94 (2% of load assumed)	2157	143	NIL	Generation: 2425 MW Load: 4700 MW
2	Vedanta		1600	32 (2% of load assumed)	NIL	1568		Load: 1600 MW

Total Import TTC for Odisha Control Area = 2394 MW+ 1600 MW = 4994 MW

* All figures are in MW