

EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH NOV-2025(R-0)

EXPORT TTC/ATC

SL. No.	Control Area	Month	Export TTC	Reliability Margin	Counterflow on Surrender of ISGS	Export ATC	Contingency	Assumptions
1	Odisha	Nov-25	1131	79 (2% of load assumed)	0	1052	Outage of one 210MW Generator of IBTPS Stage-1	Generation:5194 MW Load: 3959 MW

IMPORT TTC/ATC

SL. No.	Control Area	Month	Import TTC	Reliability Margin	Approved GNA	Import ATC	Contingency	Assumptions
1	Odisha(excluding Vedanta)	Nov-25	2650	126 (2% of load assumed)	2157	367	NIL	Generation: 3881 MW Load: 6303 MW
2	Vedanta		1600	32 (2% of load assumed)	NIL	1568		Load: 1600 MW

Total Import TTC for Odisha Control Area = 2650 MW+ 1600 MW = 4250 MW

* All figures are in MW