

## EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH DEC-2025(R-0)

### EXPORT TTC/ATC

SL. No.	Control Area	Month	Export TTC	Reliability Margin	Counterflow on Surrender of ISGS	Export ATC	Contingency	Assumptions
1	Odisha	Dec-25	1486	79 (2% of load assumed)	0	1407	Outage of one 210MW Generator of IBTPS Stage-1	Generation:5559 MW Load: 3959 MW

### IMPORT TTC/ATC

SL. No.	Control Area	Month	Import TTC	Reliability Margin	Approved GNA	Import ATC	Contingency	Assumptions
1	Odisha(excluding Vedanta)	Dec-25	2762	128 (2% of load assumed)	2157	477	NIL	Generation: 2425 MW Load: 6403 MW
2	Vedanta		1600	32 (2% of load assumed)	NIL	1568		Load: 1600 MW

Total Import TTC for Odisha Control Area = 2762 MW+ 1600 MW = 4362 MW

\* All figures are in MW