

EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH AUGUST -2019

EXPORT TTC/ATC

| SL. No. | Month | Export TTC | Reliability Margin | Counterflow on account of Surrender of LTA(ISGS) | Export ATC | Contingency | Assumptions |
|---------|-------------|------------|-------------------------------|--|------------|---|--------------------------------------|
| 1 | AUGUST-2019 | NIL | 64 MW (2% of load assumed) | 0 MW | NIL | Outage of one 220kV Jayanagar-Jeypore(PG) Ckt. | Generation: 3157 MW Load: 3200 MW |

IMPORT TTC/ATC

| SL. No. | Month | Import TTC | Reliability Margin | Import LTA(ISGS) | Import ATC | Contingency | Assumptions |
|---------|-------------|------------|-------------------------------|------------------|------------|---|--------------------------------------|
| 1 | AUGUST-2019 | 2293 MW | 91 MW (2% of load assumed) | 1150 MW | 1052 MW | Outage of one 220kV Meramundali-Bhanjanagar Ckt. | Generation: 2416 MW Load: 4562 MW |