

EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH DECEMBER -2019

EXPORT TTC/ATC

SL. No.	Month	Export TTC	Reliability Margin	Counterflow on account of Surrender of LTA(ISGS)	Export ATC	Contingency	Assumptions
1	DECEMBER-2019	820 MW	56 MW (2% of load assumed)	200 MW	964 MW	Outage of one 220kV Jayanagar-Jeypore(PG) Ckt.	Generation: 3676 MW Load: 2800 MW

IMPORT TTC/ATC

SL. No.	Month	Import TTC	Reliability Margin	Import LTA(ISGS)	Import ATC	Contingency	Assumptions
1	DECEMBER-2019	2434 MW	83 MW (2% of load assumed)	1000 MW	1351 MW	Outage of one 220kV Meramundali-Bhanjanagar Ckt.	Generation: 1822 MW Load: 4150 MW