

EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH NOVEMBER -2019

EXPORT TTC/ATC

| SL. No. | Month | Export TTC | Reliability Margin | Counterflow on account of Surrender of LTA(ISGS) | Export ATC | Contingency | Assumptions |
|---------|---------------|------------|-------------------------------|--|------------|---|--------------------------------------|
| 1 | NOVEMBER-2019 | 880 MW | 56 MW (2% of load assumed) | 200 MW | 1024 MW | Outage of one 220kV Jayanagar-Jeypore(PG) Ckt. | Generation: 3749 MW Load: 2800 MW |

IMPORT TTC/ATC

| SL. No. | Month | Import TTC | Reliability Margin | Import LTA(ISGS) | Import ATC | Contingency | Assumptions |
|---------|---------------|------------|-------------------------------|------------------|------------|---|--------------------------------------|
| 1 | NOVEMBER-2019 | 1963 MW | 80 MW (2% of load assumed) | 1150 MW | 733 MW | Outage of one 220kV Meramundali-Bhanjanagar Ckt. | Generation: 2155 MW Load: 4000 MW |