

EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH OCTOBER -2018

EXPORT TTC/ATC

SL. No.	Month	Export TTC	Reliability Margin	Counterflow on account of Surrender of LTA(ISGS)	Export ATC	Contingency	Assumptions
1	OCTOBER-2018	NIL	63 MW (2% of load assumed)	0 MW	NIL	Outage of one 220kV Jayanagar-Jeypore(PG) Ckt.	Generation: 3206MW Load: 3150MW

IMPORT TTC/ATC

SL. No.	Month	Import TTC	Reliability Margin	Import LTA(ISGS)	Import ATC	Contingency	Assumptions
1	OCTOBER-2018	1950 MW	84 MW (2% of load assumed)	1150 MW	716 MW	Outage of one 220kV Meramundali-Bhanjanagar Ckt.	Generation: 2441 MW Load: 4201 MW