

EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH SEPTEMBER -2019

EXPORT TTC/ATC

SL. No.	Month	Export TTC	Reliability Margin	Counterflow on account of Surrender of LTA(ISGS)	Export ATC	Contingency	Assumptions
1	SEPTEMBER-2019	NIL	64 MW (2% of load assumed)	0 MW	NIL	Outage of one 220kV Jayanagar-Jeypore(PG) Ckt.	Generation: 3037 MW Load: 3200 MW

IMPORT TTC/ATC

SL. No.	Month	Import TTC	Reliability Margin	Import LTA(ISGS)	Import ATC	Contingency	Assumptions
1	SEPTEMBER-2019	2391 MW	90 MW (2% of load assumed)	1150 MW	1151 MW	Outage of one 220kV Meramundali-Bhanjanagar Ckt.	Generation: 2263 MW Load: 4500 MW