

EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH AUGUST-2026(R-0)

EXPORT TTC/ATC

SL. No.	Control Area	Month	Export TTC	Reliability Margin	Counterflow on Surrender of ISGS	Export ATC	Contingency	Assumptions
1	Odisha	Aug-26	1887	92 (2% of load assumed)	0	1795	Outage of one 210MW Generator of IBTPS Stage-1	Generation:6609 MW Load: 4609 MW

IMPORT TTC/ATC

SL. No.	Control Area	Month	Import TTC	Reliability Margin	Approved GNA	Import ATC	Contingency	Assumptions
1	Odisha(excluding Vedanta)	Aug-26	2964	132 (2% of load assumed)	2157	675	NIL	Generation: 3879 MW Load: 6600 MW
2	Vedanta		1600	32 (2% of load assumed)	NIL	1568		Load: 1600 MW

Total Import TTC for Odisha Control Area =2964 MW+ 1600 MW = 4564 MW

* All figures are in MW