

EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH OCTOBER-2026(R-0)

EXPORT TTC/ATC

SL. No.	Control Area	Month	Export TTC	Reliability Margin	Counterflow on Surrender of ISGS	Export ATC	Contingency	Assumptions
1	Odisha	Oct-26	1916	86 (2% of load assumed)	0	1830	Outage of one 210MW Generator of IBTPS Stage-1	Generation: 6300 MW Load: 4305 MW

IMPORT TTC/ATC

SL. No.	Control Area	Month	Import TTC	Reliability Margin	Approved GNA	Import ATC	Contingency	Assumptions
1	Odisha(excluding Vedanta)	Oct-26	2806	132 (2% of load assumed)	2157	540	NIL	Generation: 3796 MW Load: 6450 MW
2	Vedanta		1600	32 (2% of load assumed)	NIL	1568		Load: 1600 MW

Total Import TTC for Odisha Control Area = 2806 MW + 1600 MW = 4406 MW

* All figures are in MW