EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH NOVEMBER-2026(R-0)

EXPORT TTC/ATC

SL. No.	Control Area	Month	Export TTC	Reliability Margin	Counterflow on Surrender of ISGS	Export ATC	Contingency	Assumptions
1	Odisha	Nov-26	2153	125 (2% of load assumed)	0	2028	Outage of one 210MW Generator of IBTPS Stage-1	Generation:6230MW Load: 4000 MW

IMPORT TTC/ATC

SL. No.	Control Area	Month	Import TTC	Reliability Margin	Approved GNA	Import ATC	Contingency	Assumptions
1	Odisha(excluding Vedanta)	Nov-26	2889	122 (2% of load assumed)	2157	610	NIL	Generation: 3328 MW Load: 6100 MW
2	Vedanta		1600	32 (2% of load assumed)	NIL	1568		Load: 1600 MW

Total Import TTC for Odisha Control Area =2889 MW+ 1600 MW = 4489 MW

*** All figures are in MW**