

EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH AUGUST-2027(R-0)

EXPORT TTC/ATC

SL. No.	Control Area	Month	Export TTC	Reliability Margin	Counterflow on Surrender of ISGS	Export ATC	Contingency	Assumptions
1	Odisha	Aug-27	1670	94 (2% of load assumed)	0	1576	Outage of one 210MW Generator of IBTPS Stage-1	Generation:6518 MW Load: 4701 MW

IMPORT TTC/ATC

SL. No.	Control Area	Month	Import TTC	Reliability Margin	Approved GNA	Import ATC	Contingency	Assumptions
1	Odisha(excluding Vedanta)	Aug-27	3169	140 (2% of load assumed)	2157	872	NIL	Generation: 4047 MW Load: 7023 MW
2	Vedanta		1600	32 (2% of load assumed)	NIL	1568		Load: 1600 MW

Total Import TTC for Odisha Control Area =3169 MW+ 1600 MW = 4769 MW

* All figures are in MW