

EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH SEPTEMBER-2027(R-0)

EXPORT TTC/ATC

SL. No.	Control Area	Month	Export TTC	Reliability Margin	Counterflow on Surrender of ISGS	Export ATC	Contingency	Assumptions
1	Odisha	Sep-27	1774	94 (2% of load assumed)	0	1682	Outage of one 210MW Generator of IBTPS Stage-1	Generation: 6518 MW Load: 4601 MW

IMPORT TTC/ATC

SL. No.	Control Area	Month	Import TTC	Reliability Margin	Approved GNA	Import ATC	Contingency	Assumptions
1	Odisha(excluding Vedanta)	Sep-27	2908	137 (2% of load assumed)	2157	614	NIL	Generation: 4196 MW Load: 6850 MW
2	Vedanta		1600	32 (2% of load assumed)	NIL	1568		Load: 1600 MW

Total Import TTC for Odisha Control Area = 2908 MW + 1600 MW = 4508 MW

* All figures are in MW