

EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH JANUARY -2020

EXPORT TTC/ATC

SL. No.	Month	Export TTC	Reliability Margin	Counterflow on account of Surrender of LTA(ISGS)	Export ATC	Contingency	Assumptions
1	JANUARY-2020	785 MW	60 MW (2% of load assumed)	200 MW	925 MW	Outage of one 220kV Jayanagar-Jeypore(PG) Ckt.	Generation: 3850 MW Load: 3000 MW

IMPORT TTC/ATC

SL. No.	Month	Import TTC	Reliability Margin	Import LTA(ISGS)	Import ATC	Contingency	Assumptions
1	JANUARY-2020	2554 MW	86 MW (2% of load assumed)	1000 MW	1468 MW	Outage of one 220kV Meramundali-Bhanjanagar Ckt.	Generation: 1861 MW Load: 4300 MW