

EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH MARCH -2020

EXPORT TTC/ATC

SL. No.	Month	Export TTC	Reliability Margin	Counterflow on account of Surrender of LTA(ISGS)	Export ATC	Contingency	Assumptions
1	MARCH-2020	818 MW	62 MW (2% of load assumed)	0 MW	756 MW	Outage of one 220kV Jayanagar-Jeypore(PG) Ckt.	Generation: 3982 MW Load: 3100 MW

IMPORT TTC/ATC

SL. No.	Month	Import TTC	Reliability Margin	Import LTA(ISGS)	Import ATC	Contingency	Assumptions
1	MARCH-2020	3107 MW	87 MW (2% of load assumed)	1000 MW	2020 MW	(i) Outage of one 220kV Meramundali-Bhanjanagar Ckt. (ii) Outage of OPGC Unit-3 & 4 (iii) Outage of VAL (STERLIT) Unit-2	Generation: 1357 MW Load: 4350 MW