

## EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH DECEMBER -2020

### EXPORT TTC/ATC

SL. No.	Month	Export TTC	Reliability Margin	Counterflow on account of Surrender of LTA(ISGS)	Export ATC	Contingency	Assumptions
1	DECEMBER-2020	1432 MW	54 MW (2% of load assumed)	700 MW	2078 MW	Outage of one 220kV Jayanagar-Jeypore(PG) Ckt.	Generation: 4202 MW Load: 2706 MW

### IMPORT TTC/ATC

SL. No.	Month	Import TTC	Reliability Margin	Import LTA(ISGS)	Import ATC	Contingency	Assumptions
1	DECEMBER-2020	2251 MW	74 MW (2% of load assumed)	700 MW	1477 MW	(i) Outage of one 220kV Tarkera-Rourkela(PG) Ckt. (ii) Outage of OPGC Unit- 4 (iii) Outage of VAL (STERLIT) Unit-2	Generation: 1566 MW Load: 3705 MW