

EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH AUGUST -2020

EXPORT TTC/ATC

SL. No.	Month	Export TTC	Reliability Margin	Counterflow on account of Surrender of LTA(ISGS)	Export ATC	Contingency	Assumptions
1	AUGUST-2020	1071 MW	60 MW (2% of load assumed)	400 MW	1411 MW	Outage of one 220kV Jayanagar-Jeypore(PG) Ckt.	Generation: 4128 MW Load: 3000 MW

IMPORT TTC/ATC

SL. No.	Month	Import TTC	Reliability Margin	Import LTA(ISGS)	Import ATC	Contingency	Assumptions
1	AUGUST-2020	2112 MW	83 MW (2% of load assumed)	800 MW	1229 MW	(i) Outage of one 220kV Tarkera-Rourkela(PG) Ckt. (ii) Outage of OPGC Unit- 4 (iii) Outage of VAL (STERLIT) Unit-2	Generation: 2177 MW Load: 4162 MW