

EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH MAY-2021

EXPORT TTC/ATC

SL. No.	Month	Export TTC	Reliability Margin	Counterflow on account of Surrender of LTA(ISGS)	Export ATC	Contingency	Assumptions
1	MAY-2021	961 MW	63 MW (2% of load assumed)	400 MW	1298 MW	Outage of one 220kV Jayanagar-Jeypore(PG) Ckt.	Generation: 4185 MW Load: 3150 MW

IMPORT TTC/ATC

SL. No.	Month	Import TTC	Reliability Margin	Import LTA(ISGS)	Import ATC	Contingency	Assumptions
1	MAY-2021	2712 MW	91 MW (2% of load assumed)	1000 MW	1621 MW	(i) Outage of one 220kV N. Bolangir-Bolangir(PG) Ckt. (ii) Outage of OPGC Unit- 4 (iii) Outage of VAL (STERLIT) Unit-2	Generation: 1984 MW Load: 4538 MW