

EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH DECEMBER-2021

EXPORT TTC/ATC

SL. No.	Month	Export TTC	Reliability Margin	Counterflow on account of Surrender of LTA(ISGS)	Export ATC	Contingency	Assumptions
1	DECEMBER-2021	1040	55MW (2% of load assumed)	300 MW	1285 MW	Outage of OPGC Unit-4	Generation: 3885MW Load: 2700 MW

IMPORT TTC/ATC

SL. No.	Month	Import TTC	Reliability Margin	Import LTA(ISGS)	Import ATC	Contingency	Assumptions
1	DECEMBER-2021	2412 MW	100 MW (2% of load assumed)	1200 MW	912	Outage of one 220kV Tarkera-Rourkela(PG) Ckt.	Generation: 2806MW Load:4999 MW