

EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH JUNE-2022

EXPORT TTC/ATC

SL. No.	Control Area	Month	Export TTC	Reliability Margin	Counterflow on account of Surrender of LTA(ISGS)	Export ATC	Contingency	Assumptions
1	Odisha	JUNE-22	1262	98 MW (2% of load assumed)	200	1364 MW	Outage of one 210MW Generator of IBTPS Stage-1	Generation: 4901 MW Load: 3550 MW

IMPORT TTC/ATC

SL. No.	Control Area	Month	Import TTC	Reliability Margin	Import LTA(ISGS)	Import ATC	Contingency	Assumptions
1	Odisha(excluding Vedanta)	JUNE-22	1858	92 MW (2% of load assumed)	1000 MW	766 MW	Outage of one 220kV Tarkera-Rourkela(PG) Ckt.*	Generation: 2899MW Load:4601 MW
2	Vedanta		1400	34 MW (2% of load assumed)	NIL	1366MW	Outage of one 400kV OPGC-Lapanga ckt	Generation: 350MW Load:1751MW

Total Import TTC for Odisha Control Area= 1858MW+ 1400MW= 3258MW

* SPS has been designed for 220kV Tarkera-Rourkela PG line. So, this ckt is not a constraint