

## EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH JULY-2024(R-1)

### EXPORT TTC/ATC

SL. No.	Control Area	Month	Export TTC	Reliability Margin	Counterflow on Surrender of ISGS	Export ATC	Contingency	Assumptions
1	Odisha	Jul-24	933	80 MW (2% of load assumed)	0	853	Outage of one 210MW Generator of IBTPS Stage-1	Generation:5028 MW Load: 4001 MW

### IMPORT TTC/ATC

SL. No.	Control Area	Month	Import TTC	Reliability Margin	Approved GNA	Import ATC	Contingency	Assumptions
1	Odisha(excluding Vedanta)	Jul-24	3315	112 MW (2% of load assumed)	2157 MW	1046 MW	NIL	Generation: 2463 MW Load: 5603 MW
2	Vedanta		1600	32 MW (2% of load assumed)	NIL	1568 MW		Load: 1600 MW

Total Import TTC for Odisha Control Area = 3315 MW+ 1600 MW = 4915 MW