

EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH AUG-2024(R-0)

EXPORT TTC/ATC

SL. No.	Control Area	Month	Export TTC	Reliability Margin	Counterflow on Surrender of ISGS	Export ATC	Contingency	Assumptions
1	Odisha	Aug-24	1019	80 MW (2% of load assumed)	0	939	Outage of one 210MW Generator of IBTPS Stage-1	Generation:5121 MW Load: 4000 MW

IMPORT TTC/ATC

SL. No.	Control Area	Month	Import TTC	Reliability Margin	Approved GNA	Import ATC	Contingency	Assumptions
1	Odisha(excluding Vedanta)	Aug-24	2587	112 MW (2% of load assumed)	2157 MW	318 MW	NIL	Generation: 3196 MW Load: 5600 MW
2	Vedanta		1600	32 MW (2% of load assumed)	NIL	1568 MW		Load: 1600 MW

Total Import TTC for Odisha Control Area = 2587 MW+ 1600 MW = 4187 MW