

EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH OCT-2024(R-0)

EXPORT TTC/ATC

SL. No.	Control Area	Month	Export TTC	Reliability Margin	Counterflow on Surrender of ISGS	Export ATC	Contingency	Assumptions
1	Odisha	Oct-24	926	80 MW (2% of load assumed)	0	846	Outage of one 210MW Generator of IBTPS Stage-1	Generation:5200 MW Load: 4000 MW

IMPORT TTC/ATC

SL. No.	Control Area	Month	Import TTC	Reliability Margin	Approved GNA	Import ATC	Contingency	Assumptions
1	Odisha(excluding Vedanta)	Oct-24	2556	118 MW (2% of load assumed)	2157 MW	281 MW	NIL	Generation: 3543 MW Load: 5900 MW
2	Vedanta		1600	32 MW (2% of load assumed)	NIL	1568 MW		Load: 1600 MW

Total Import TTC for Odisha Control Area = 2556 MW+ 1600 MW = 4156 MW