

EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH NOV-2024(R-0)

EXPORT TTC/ATC

SL. No.	Control Area	Month	Export TTC	Reliability Margin	Counterflow on Surrender of ISGS	Export ATC	Contingency	Assumptions
1	Odisha	Nov-24	1202	74 (2% of load assumed)	0	1128	Outage of one 210MW Generator of IBTPS Stage-1	Generation:5013 MW Load: 3678 MW

IMPORT TTC/ATC

SL. No.	Control Area	Month	Import TTC	Reliability Margin	Approved GNA	Import ATC	Contingency	Assumptions
1	Odisha(excluding Vedanta)	Nov-24	2412	110 (2% of load assumed)	2157	145	NIL	Generation: 3543 MW Load: 5501 MW
2	Vedanta		1600	32 (2% of load assumed)	NIL	1568		Load: 1600 MW

Total Import TTC for Odisha Control Area = 2412 MW+ 1600 MW = 4012 MW

* All figures are in MW