

EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH MARCH-2025(R-0)

EXPORT TTC/ATC

SL. No.	Control Area	Month	Export TTC	Reliability Margin	Counterflow on Surrender of ISGS	Export ATC	Contingency	Assumptions
1	Odisha	Mar-25	1701	80 (2% of load assumed)	0	1621	Outage of one 210MW Generator of IBTPS Stage-1	Generation:5804 MW Load: 4000 MW

IMPORT TTC/ATC

SL. No.	Control Area	Month	Import TTC	Reliability Margin	Approved GNA	Import ATC	Contingency	Assumptions
1	Odisha(excluding Vedanta)	Mar-25	2834	110 (2% of load assumed)	2157	567	NIL	Generation: 2837 MW Load: 5501 MW
2	Vedanta		1600	32 (2% of load assumed)	NIL	1568		Load: 1600 MW

Total Import TTC for Odisha Control Area = 2834 MW+ 1600 MW = 4434 MW

* All figures are in MW