

EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH FEB-2026(R-0)

EXPORT TTC/ATC

SL. No.	Control Area	Month	Export TTC	Reliability Margin	Counterflow on Surrender of ISGS	Export ATC	Contingency	Assumptions
1	Odisha	Feb-26	1644	83 (2% of load assumed)	0	1561	Outage of one 210MW Generator of IBTPS Stage-1	Generation:5922 MW Load: 4161 MW

IMPORT TTC/ATC

SL. No.	Control Area	Month	Import TTC	Reliability Margin	Approved GNA	Import ATC	Contingency	Assumptions
1	Odisha(excluding Vedanta)	Feb-26	2807	130 (2% of load assumed)	2157	520	NIL	Generation: 3922 MW Load: 6501 MW
2	Vedanta		1600	32 (2% of load assumed)	NIL	1568		Load: 1600 MW

Total Import TTC for Odisha Control Area = 2807 MW+ 1600 MW = 4407 MW

* All figures are in MW