

## EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH MARCH-2026(R-0)

### EXPORT TTC/ATC

| SL. No. | Control Area | Month  | Export TTC | Reliability Margin          | Counterflow on Surrender of ISGS | Export ATC | Contingency                                    | Assumptions                         |
|---------|--------------|--------|------------|-----------------------------|----------------------------------|------------|------------------------------------------------|-------------------------------------|
| 1       | Odisha       | Mar-26 | 1701       | 129<br>(2% of load assumed) | 0                                | 1572       | Outage of one 210MW Generator of IBTPS Stage-1 | Generation:6433 MW<br>Load: 4604 MW |

### IMPORT TTC/ATC

| SL. No. | Control Area              | Month  | Import TTC | Reliability Margin          | Approved GNA | Import ATC | Contingency | Assumptions                          |
|---------|---------------------------|--------|------------|-----------------------------|--------------|------------|-------------|--------------------------------------|
| 1       | Odisha(excluding Vedanta) | Mar-26 | 2906       | 132<br>(2% of load assumed) | 2157         | 617        | NIL         | Generation: 3942 MW<br>Load: 6600 MW |
| 2       | Vedanta                   |        | 1600       | 32<br>(2% of load assumed)  | NIL          | 1568       |             | Load: 1600 MW                        |

Total Import TTC for Odisha Control Area = 2906 MW+ 1600 MW = 4506 MW

\* All figures are in MW